

SYLLABUS / 2015 BATCH

ТРС

3 0 0 3

L



# KARPAGAM ACADEMY OF HIGHER EDUCATION

(Deemed to be University Established Under Section 3 of UGC Act 1956) Eachanari post, Coimbatore-641021. INDIA.

# Faculty of Engineering DEPARTMENT OF MECHANICAL ENGINEERING

# SUBJECT NAME : HEAT POWER ENGINEERING

# SUBJECT CODE : 15BEME501

**INTENDED OUTCOMES:** 

- To integrate the concepts, laws and methodologies from the first course in thermodynamics into the analysis of cyclic process.
- To apply the thermodynamic concepts into various thermal applications like Steam turbines, Compressors and Refrigeration and Air conditioning Systems.

#### UNIT I GAS POWER CYCLES AND IC ENGINES

Otto, Diesel, Dual, Brayton cycles – Calculation of mean effective pressure and air standard efficiency – actual and theoretical PV diagrams of two stroke and four stroke engines–valve timing diagram and port timing diagram – calculation of engine performance, heat balance sheet, retardation – Morse test.

#### UNIT II BOILER AND STEAM POWER CYCLES

Generation of steam, Boiler–Classification, fire tube boiler, water tube boiler, comparison, boiler mountings and accessories, performance of steam boilers – dryness fraction, properties of steam, T–S diagram, Mollier diagram, steam tables, Rankine Cycle – incomplete evaporation – superheated steam –modified cycle.

#### UNIT III STEAM NOZZLES AND STEAM TURBINES

Steam nozzles – flow through steam nozzles, effect of friction, critical pressure ratio, super saturated flow – Steam turbines– impulse and reaction turbine, compounding, velocity diagram, condition for maximum efficiency – multi stage turbines, cycles with reheating and regenerating heating – reheat factor, degree of reaction, governing of turbines.

#### UNIT IV AIR COMPRESSORS

Classifications of compressors – Reciprocating air compressor – performance characteristics, effect of clearance volume, free air delivery and displacement, intercooler, after cooler – Rotary compressor – vane type, centrifugal and axial, flow performance characteristics.

#### UNIT V REFRIGERATION AND AIR CONDITIONING

Fundamentals of refrigeration – COP – Vapour compression refrigeration system – cycle, p–h chart, Vapour absorption system – comparison, properties of refrigerants. Fundamentals of air conditioning system, cycle, controls, air handling and distribution, simple cooling and heat load estimation

(Use of standard thermodynamic table, Mollier diagram, Psychometric chart and Refrigeration property table is permitted in the examination)

# **TEXT BOOKS:**

15BEME501

S.NO	AUTHOR(S) NAME	TITLE OF THE BOOK	PUBLISHER	YEAR OF PUBLICATION
1	Rajput R.K	Thermal Engineering, Sixth edition	Laxmi Publications, New Delhi.	2010
2	Arora C.P	Refrigeration and Air conditioning	Tata McGraw–Hill, New Delhi.	2002

#### **REFERENCES:**

S.NO	AUTHOR(S) NAME	TITLE OF THE BOOK	PUBLISHER	YEAR OF PUBLICATION
1	Kothandaraman C.P, Domkundwar and Domkundwar A.V	A course in Thermal Engineering, Fifth Edition	Dhanpat Rai and Sons, Delhi.	2002
2	Ganesan V	Internal Combustion Engines	Tata McGraw–Hill, New Delhi.	2008
3	Yunus A Cengel	'Thermodynamics' An Engineering Approach	Third Edition, Tata McGraw Hill, New Delhi.	2008

#### **WEBSITES :**

- 1. <u>www.kruse-ltc.com</u>

- www.grc.nasa.gov
   www.poweronsite.org
   www.machinerylubrication.com
   www.tpub.com
- 6. <u>www.engineeringtoolbox.com</u>
- 7. www.scribd.com



LESSON PLAN / 2015 BATCH

:15BEME501



# KARPAGAM ACADEMY OF HIGHER EDUCATION

(Deemed to be University Established Under Section 3 of UGC Act 1956) Eachanari post, Coimbatore-641021. INDIA.

**Subject Code** 

Faculty of Engineering DEPARTMENT OF MECHANICAL ENGINEERING

# **LESSON PLAN**

: HEAT POWER ENGINEERING

#### **Subject Name**

	•		
Sl. No.	No. of Periods	Topics to be Covered	Support Materials
		<u>UNIT – I : GAS POWER CYCLES AND IC ENGINES</u>	
1.	1	Otto cycle - Calculation of Mean Effective Pressure and Air Standard Efficiency	T[1], <b>R</b> [3]
2.	1	Problems related to Otto cycle	T[1], <b>R</b> [3]
3.	1	Diesel cycle - Calculation of Mean Effective Pressure and Air Standard Efficiency	T[1], <b>R</b> [3]
4.	1	Problems related to Diesel cycle	T[1], <b>R</b> [3]
5.	1	Dual cycle - Calculation of Mean Effective Pressure and Air Standard Efficiency	T[1], <b>R</b> [3]
6.	1	Problems related to Dual cycle	T[1], <b>R</b> [3]
7.	1	Brayton cycle - Calculation of Mean Effective Pressure and Air Standard Efficiency	T[1], <b>R</b> [3]
8.	1	Problems related to Brayton cycle	T[1], <b>R</b> [3]
9.	1	Tutorial-1: Problems related to Gas Power Cycles	T[1], R[3]
10.	1	Classification of I.C engines Basics of two stroke and four stroke engines	T[1], R[2]
11.	1	Actual and theoretical PV diagrams of two stroke and four stroke engines, Valve timing diagram and port timing diagram	T[1], R[2]
12.	1	Calculation of engine performance and Heat balance Problems in heat balance sheet	T[1], R[2]
13.	1	Calculation of engine performance and Heat balance Problems in heat balance sheet	T[1], R[2]
14.	1	Tutorial-2: Problems related to IC Engines	T[1], R[2]
		Total No. of Hours Planned for Unit - I	14

Sl. No.	No. of Periods	Topics to be Covered	Support Materials
		<u>UNIT – II : BOILER AND STEAM POWER CYCLES</u>	
15.	1	Fundamentals of steam generation and Boiler	T[1], <b>R</b> [1]
16.	1	Classification of boilers and comparison of the boilers	T[1], R[1], W[6]
17.	1	Boiler mountings	T[1], R[1], W[6]
18.	1	Boiler accessories	T[1], R[1], W[6]
19.	1	Calculating performance of steam boilers	T[1], R[1], W[6]
20.	1	Problems related to Steam Boilers	T[1], R[1], W[6]
21.	1	Tutorial-3: Problems Related to Steam Boilers	T[1], <b>R</b> [1]
22.	1	Determination of Dryness fraction of steam, properties of steam	T[1], <b>R</b> [3]
23.	1	T–S diagram, Mollier diagram, steam tables	T[1], <b>R</b> [3]
24.	1	Rankine Cycle and incomplete evaporation of steam	T[1], <b>R</b> [3]
25.	1	Superheated steam and modified cycle	T[1], <b>R</b> [3]
26.	1	Problems related to Steam power cycle	T[1], <b>R</b> [3]
27.	1	<b>Tutorial-4: Problems Related to Steam Power Cycles</b>	T[1], <b>R</b> [3]
	13		

Sl.	No. of	Topics to be Covered	Support Materials	
No.	Periods		Support muterius	
		<u>UNIT – III : </u> STEAM NOZZLES AND STEAM TURBINES		
28.	1	Steam nozzles- flow through steam nozzles, effect of friction, and critical pressure ratio	T[1], R[3], W[6]	
29.	1	Super saturated flow and Problems related to steam nozzles	T[1], <b>R</b> [3], W[6]	
30.	1	Problems related to steam nozzles	T[1], <b>R</b> [3]	
31.	1	Problems related to steam nozzles	T[1], <b>R</b> [3]	
32.	1	Steam turbines- impulse and reaction turbine, compounding, velocity diagram	T[1], <b>R</b> [3], W[6]	
33.	1	Condition for maximum efficiency of steam turbines, Multi stage turbines	T[1], R[3]	
34.	1	Tutorial-5: Problems Related to Steam Nozzles	T[1], <b>R</b> [3]	
35.	1	Cycles with reheating and regenerating heating, Reheat factor	T[1], <b>R</b> [1]	
36.	1	Degree of reaction, governing of turbines	T[1], R[1], W[6]	
37.	1	Problems related to Steam turbine	T[1], <b>R</b> [1]	
38.	1	Tutorial-6: Problems Related to Steam Turbines	T[1], <b>R</b> [1]	
	Total No. of Hours Planned for Unit - III			

SI. No.	No. of Periods	Topics to be Covered	Support Materials			
	<u>UNIT – IV :</u> AIR COMPRESSORS					
39.	1	Classifications of compressors Reciprocating air compressor - performance characteristics	T[1], <b>R</b> [1]			
40.	1	Effect of clearance volume in Reciprocating Compressor	T[1], <b>R</b> [1]			

15BEME501		HEAT POWE	<b>R ENGINEERING</b>
41.	1	Free air delivery and displacement in Reciprocating Compressor	T[1], <b>R</b> [1]
42.	1	Problems related to Reciprocating Compressor	T[1], <b>R</b> [1]
43.	1	<b>Tutorial-7: Problems Related to Reciprocating Compressor</b>	T[1], <b>R</b> [1]
44.	1	Intercooler, after cooler Rotary compressor - vane type	T[1], <b>R</b> [1]
45.	1	Centrifugal and axial, flow performance characteristics	T[1], R[1]
46.	1	Comparison of different types of compressors	T[1], R[1]
47.	1	Problems related to Rotary Compressor	T[1], <b>R</b> [1]
48.	1	<b>Tutorial-8: Problems Related to Rotary Compressor</b>	T[1], <b>R</b> [1]
		Total No. of Hours Planned for Unit - IV	10

SI. No.	No. of Periods	Topics to be Covered	Support Materials	
	•	<b><u>UNIT – V :</u> REFRIGERATION AND AIR CONDITIONING</b>		
49.	1	Fundamentals of refrigeration and COP	T[2], R[1]	
50.	1	Refrigerants – types, properties, applications	T[2], <b>R</b> [1]	
51.	1	Vapour compression refrigeration system - cycle, p-h chart	T[2], R[1], W[6]	
52.	1	Vapour absorption system- comparison, properties of refrigerants	T[2], R[1], W[6]	
53.	1	Problems related to vapour compression refrigeration system	T[2], R[1]	
54.	1	Problems related to vapour compression refrigeration system	T[2], R[1]	
55.	1	Tutorial-9: Problems Related to Refrigeration Systems	T[2], R[1]	
56.	1	Fundamentals of air conditioning system, cycle, control	T[2], R[1], W[6]	
57.	1	Air handling and air distribution systems in Air conditioning system	T[2], R[1]	
58.	1	Simple cooling and heat load estimation and problems	T[2], R[1]	
59.	1	Problems related to Cooling and Heat load Estimations	T[2], R[1]	
60.	1	Tutorial-10: Problems Related to Air Conditioning Systems	T[2], R[1]	
	Total No. of Hours Planned for Unit - V			

## **TEXT BOOKS**

T [1] – Rajput R.K, 2010, Thermal Engineering, Sixth edition, Laxmi Publications, New Delhi T [2] – Arora C.P, 2002, Refrigeration and Air conditioning, Tata McGraw–Hill, New Delhi

## REFERENCES

R [1] - Kothandaraman C.P, and Domkundwar A.V, 2006, A course in Thermal Engineering, Dhanpatrai and sons, New Delhi

- R [2] Ganesan V, 2008, Internal Combustion Engines, Tata McGraw-Hill, New Delhi
- R [3] Yunus A Cengel, 2008, 'Thermodynamics' An Engineering Approach, Tata McGraw-Hill, New Delhi

#### WEBSITES

- W [1] www.kruse–ltc.com
- W [2] www.grc.nasa.gov
- W [3] www.poweronsite.org

- W [4] www.machinerylubrication.com
- W [5] www.tpub.com
- W [6] <u>www.nptel.ac.in</u>



#### JOURNALS

- J [1] Journal of Thermal Sciences
- J [2] Journal of Heat and Mass Transfer

**TOTAL NUMBER OF COURSE HOURS : 60 Hrs** 

# UNIT – I GAS POWER CYCLES AND IC ENGINES

#### The Otto Cycle :

The Otto cycle, which was first proposed by a Frenchman, Beau de Rochas in 1862, was first used on an engine built by a German, Nicholas A. Otto, in 1876. The cycle is also called a constant volume or explosion cycle. This is the equivalent air cycle for reciprocating piston engines using spark ignition.

At the start of the cycle, the cylinder contains a mass M of air at the pressure and volume indicated at point 1. The piston is at its lowest position. It moves upward and the gas is compressed isentropically to point 2. At this point, heat is added at constant volume which raises the pressure to point 3. The high pressure charge now expands isentropically, pushing the piston down on its expansion stroke to point 4 where the charge rejects heat at constant volume to the initial state, point 1. The isothermal heat addition and rejection of the Carnot cycle are replaced by the constant volume processes which are, theoretically more plausible, although in practice, even these processes are not practicable. The heat supplied, Qs, per unit mass of charge, is given by

cv(T3 - T2)

the heat rejected, Qr per unit mass of charge is given by

cv(T4 - T1)

Figure 3 shows a plot of thermal efficiency versus compression ratio for an Otto cycle. It is seen that the increase in efficiency is significant at lower compression ratios. This is also seen in Table 1 given below.



Fig.3: variation of efficiency with compression ratio Table1: compression ratio and corresponding thermal efficiency for Otto cycle

R	η
1	0
2	0.242
3	0.356
4	0.426
5	0.475
6	0.512
7	0.541
8	0.565
9	0.585
10	0.602
16	0.67
20	0.698
50	0.791

From the table it is seen that if: CR is increased from 2 to 4, efficiency increase is 76% CR is increased from 4 to 8, efficiency increase is only 32.6% CR is increased from 8 to 16, efficiency increase is only 18.6% **Mean effective pressure and air standard efficiency** It is seen that the air standard efficiency of the Otto cycle depends only on the compression ratio. However, the pressures and temperatures at the various points in the cycle and the net work done, all depend upon the initial pressure and temperature and the heat input from point 2 to point 3, besides the compression ratio. A quantity of special interest in reciprocating engine analysis is the mean effective pressure. Mathematically, it is the net work done on the piston, W, divided by the piston displacement volume, V1 - V2. This quantity has the units of pressure. Physically, it is that constant pressure which, if exerted on the piston for the whole outward stroke, would yield work equal to the work of the cycle. It is given by

## MEP=W/(V1-V2)

# **Diesel Cycle :**

This cycle, proposed by a German engineer, Dr. Rudolph Diesel to describe the processes of his engine, is also called the constant pressure cycle. This is believed to be the equivalent air cycle for the reciprocating slow speed compression ignition engine. The P-V and T-s diagrams are shown in Figs 4 and 5 respectively.



The cycle has processes which are the same as that of the Otto cycle except that the heat is added at constant pressure. The heat supplied, Qs is given by

$$cp(T3 - T2)$$

whereas the heat rejected, Qr is given by

$$cv(T4 - T1)$$



Fig.6: P-V Diagram of Dual Cycle.

Process 1-2: Reversible adiabatic compression.

- Process 2-3: Constant volume heat addition.
- Process 3-4: Constant pressure heat addition.
- Process 4-5: Reversible adiabatic expansion.
- Process 5-1: Constant volume heat reject





#### 15BEME501

HEAT POWER ENGINEERING

The cycle is the equivalent air cycle for reciprocating high speed compression ignition engines. The P-V and T-s diagrams are shown in Figs.6 and 7. In the cycle, compression and expansion processes are isentropic; heat addition is partly at constant volume and partly at constant pressure while heat rejection is at constant volume as in the case of the Otto and Diesel cycles. The heat supplied, Qs per unit mass of charge is given by

$$cv(T3 - T2) + cp(T3'' - T2)$$

whereas the heat rejected, Qr per unit mass of charge is given by

cv(T4 - T1)

## The Brayton Cycle:

The Brayton cycle is also referred to as the Joule cycle or the gas turbine air cycle because all modern gas turbines work on this cycle. However, if the Brayton cycle is to be used for reciprocating piston engines, it requires two cylinders, one for compression and the other for expansion. Heat addition may be carried out separately in a heat exchanger or within the expander itself. The pressure-volume and the corresponding temperature-entropy diagrams are shown in Figs 10 and 11 respectively.



**Fig.10** 





The cycle consists of an isentropic compression process, a constant pressure heat addition process, an isentropic expansion process and a constant pressure heat rejection process. Expansion is carried out till the pressure drops to the initial (atmospheric) value. Heat supplied in the cycle, Qs, is given by

Cp(T3 - T2)

Heat rejected in the cycle, Qs, is given by

Cp(T4 - T1)

Actual PV diagram of four stroke engine



Theoretical PV diagram for four stroke engine



Theoretical and Actual PV diagram of Two stroke Petrol Engine:



# **Problems: Problems to determine,**

1. Air Standard Efficiency

2. Mean Effective Pressure for Air Standard Cycles

**Sample Problems** 1. A Dual combustion air standard cycle has a compression ratio of 10. The constant pressure part of combustion takes place at 40 bar. The highest and the lowest temperature of the cycle are  $1727^{\circ}$  C and  $27^{\circ}$  C respectively. The pressure at the beginning of compression is 1 bar. Calculate- (i) The pressure and temperature at key points of the cycle. (ii) The heat supplied at constant volume, (iii) The heat supplied at constant pressure (iv) The heat rejected (*v*) The Work output, (vi) The efficiency and (vii) Mean effective pressure.

2. An Engine working on Otto cycle has a volume of 0.45 m3, pressure 1 bar and temperature 30Oc, at the beginning of compression stroke. At the end of Compression stroke, the pressure is 11 bar and 210 KJ of heat is added at constant Volume. Determine

i. Pressure, temperature and volumes at salient points in the cycle.

ii. Efficiency.

# **Classification of IC engine:**

Normally IC engines are classified into

1.C.I engines and

2.S.I engines

Some of the important classifications are given below,

1. Number of strokes

-two stroke and four stroke

2. Working Cycles

-Otto ,Diesel, Dual cycle

3. Cylinder arrangement

-In-line, V-type, Opposed, Radial

4. Valve Arrangement -T-head, F-head, L-head, I-head

## 5.Fuel Used

-Petrol, Diesel, Gas

6. Combustion chamber design

-Open, divided

- 7. Cooling System
  - -Water and air cooling

8. According to the number of cylinders

-Single and Multi

9. According to the speed

-Slow, medium, and high speed engines

10. According to the application

-Stationary, Automotive, Marine, Locomotive, Aircraft etc.,

# **Components of I.C engine:**

# 1.Cylinder block:

The cylinder block is the main body of the engine, the structure that supports all the other components of the engine. In the case of the single cylinder engine the cylinder block houses the cylinder, while in the case of multi-cylinder engine the number of cylinders are cast together to form the cylinder block. The cylinder head is mounted at the top of the cylinder block. When the vehicle runs, large amounts of heat are generated within the cylinder block. To remove this heat the cylinder block and the cylinder head are cooled by water flowing through the water jackets within larger engines such as those found in cars and trucks. For smaller vehicles like motorcycles, fins are provided on the cylinder block and on the cylinder head to cool them. The bottom portion of the cylinder block is called a crankcase. Within the crankcase is where lubricating oil, which is used for lubricating various moving parts of the engine, is stored.

## 2) Cylinder:

As the name suggests it is a cylindrical shaped vessel fitted in the cylinder block. This cylinder can be removed from the cylinder block and machined whenever required to. It is also called a liner or sleeve. Inside the cylinder the piston moves up and down, which is called the reciprocating motion of the piston. Burning of fuel occurs at the top of the cylinder, due to which the reciprocating motion of the piston is produced. The surface of the cylinder is finished to a high finish, so that there is minimal friction between the piston and the cylinder. **3) Piston:** 

The piston is the round cylindrical component that performs a reciprocating motion inside the cylinder. While the cylinder itself is the female part, the piston is the male part. The piston fits perfectly inside the cylinder. Piston rings are fitted over the piston. The gap between the piston and the cylinder is filled by the piston rings and lubricating oil. The piston is usually made up of aluminium.

# 4) Piston rings:

The piston rings are thin rings fitted in the slots made along the surface of the piston. It provides a tight seal between the piston and the cylinder walls that prevents leaking of the combustion gases from one side to the other. This ensures that that motion of the piston produces as close as to the power generated from inside the cylinder.

# 5) Combustion chamber:

It is in the combustion chamber where the actual burning of fuel occurs. It is the uppermost portion of the cylinder enclosed by the cylinder head and the piston. When the fuel is burnt, much thermal energy is produced which generates excessively high pressures causing the reciprocating motion of the piston.

# 6) Inlet manifold:

Through the inlet manifold the air or air-fuel mixture is drawn into the cylinder.

## 7) Exhaust manifold:

All the exhaust gases generated inside the cylinder after burning of fuel are discharged through the exhaust manifold into the atmosphere.

## 8) Inlet and exhaust valves:

#### **15BEME501**

#### HEAT POWER ENGINEERING

The inlet and the exhaust valves are placed at the top of the cylinder in the cylinder head. The inlet valve allows the intake of the fuel during suction stroke of the piston and to close thereafter. During the exhaust stroke of the piston the exhaust valves open allowing the exhaust gases to release to the atmosphere. Both these valves allow the flow of fuel and gases in single direction only.

# 9) Spark plug:

The spark plug is a device that produces a small spark that causes the instant burning of the pressurized fuel.

# 10) Connecting rod:

It is the connecting link between the piston and the crankshaft that performs the rotary motion. There are two ends of the connecting rod called the small end and big end. The small end of the connecting rod is connected to the piston by gudgeon pin, while the big end is connected to crankshaft by crank pin.

# 11) Crankshaft:

The crankshaft performs the rotary motion. It is connected to the axle of the wheels which move as the crankshaft rotates. The reciprocating motion of the piston is converted into the rotary motion of the crankshaft with the help of connecting rod. The crankshaft is located in the crankcase and it rotates in the bushings.

# 12) Camshaft:

It takes driving force from crankshaft through gear train or chain and operates the inlet valve as well as exhaust valve with the help of cam followers, push rod and rocker arms.

# Theoretical valve timing diagram of four stroke engine:



# Actual valve timing diagram of four stroke engine:



## Theoretical port timing diagram of two stroke engine:



1- IPO 2- IPC 3- EPO 4- TPO 5- TPC 6-EPC

# Comparison of two stroke and four stroke engines:

SI No.	Four stroke Cycle engine	Two Stroke Cycle Engine
1	For every two revolutions of the crankshaft, there is one power stroke i.e., after every four piston strokes.	For every one revolution of the crankshaft, there is one power stroke i.e., after every two piston strokes.
2	For some power, more space is required.	For the same power less space is required.
3	Valves are required - inlet and exhaust valves.	Ports are made in the cylinder walls - inlet, exhaust and transfer port.
4	As the valves move frequently, lubrication is essential.	Arrangement of ports, reduce wear and tear and lubrication is not very essential.
5	Heavier flywheel is required because the turning moment (torque) of the crankshaft is not uniform i.e. one working stroke in every two revolution.	Lighter flywheel is required because the turning moment of the crankshaft is much more uniform i.e. one working stroke for every revolution.
6	These engines are water cooled, making it complicated in design and difficulty to maintain	These engines are generally air cooled, simple in design and easy to maintain.
7	The fuel-air change (mixture) is completely utilized thus efficiency is higher	As inlet and outlet port open simultaneous, some times fresh charge escapes with the exhaust gases are not always completely removed. This causes lower efficiency

# Comparison of petrol and diesel engine:

SI. No.	Petrol Engine	Diesel Engine
1	The exhaust is less noisy.	The exhaust is noisy due
		to short time available for
		exhaust.
2	Intake (Petrol) and	Air alone is admitted
	air is admitted into	into the cylinder during
	the cylinder during	suction stroke.
	suction stroke.	
3	Fuel Ignition: - By spark	By the compressed
0.000	plug -Spark Ignition (SI)	hot air Compression
	engine.	Ignition (CI) Engine.
4	Cycle of operation: - Otto	Diesel Cycle.
	cycle (constant volume	Diese, Sjole,
	cycle (constant volance	
5	Compression Ratio Low (7	High (16 to 17)
	to	111g1 (10 to 17).
	01	
6	oj.	Through fuel injector
0	ruel aumission	Infougri fuel injector.
	Inrough carburetor.	
	Engine speed: - nign	Low speed; about up to
	speed; can run up to 5000	3500 rpm
	rpm since petrol engine	
-	is lighter.	
0	Weight:- Because of	Higher compression ratio
	low compression ratio,	in diesel engines result
	the engine cylinder	in higher pressure,
	undergoes less	therefore diesel engines
	pressure. It weights about	are sturdier and heavier.
	0.5 to 3 kg per KW (kilo	Diesel engine weights
	watt) of power produced.	about 2 to 10 kg per KW of
		power produced
9	Lubricating Property: -	Diesel has lubricating
	Petrol does not have	properties.
	lubricating properties	
10	Engine starting in	Greater cranking effort is
	cold condition is easy	required to overcome the
		higher compression ratio,
		due to the cold air in the
		combustion chamber.
11	Fire hazard: - Petrol is	Diesel 'is less volatile and
	highly volatile and there is	has a reduced risk of fire.
	a greater risk of fire.	
12	Engine cost: - Less costly	More costly since the fuel
	since the fuel systems	injection system used are
	used are not expensive.	expensive.
13	Fuel Consumption: - more	Less
14	Fuel cost: - More	Less
15	Maintenance cost: - Less	More skill is required for
	skill is required. Spark	repair of injection
	plugs are not expensive.	equipment. Fuel injectors
~		are very expansive.
16	Space:- For the same	For the same output, more
	power output, Petrol	space is required for
	engine occupies lesser	diesel engine.
	space.	
17	Engine life: - Less than	More than 1,50,000 km
	60000 KM	
18	Vibration and noise: - Very	More due to high
	less	operation pressure
		(compression ratio)

# 15BEME501

# MULITIPLE CHOICE QUESTIONS:

Questions	opt1	opt2	opt3	opt4	answer
The ratio of indicated thermal efficiency to the corresponding air standard cycle efficiency is called	net efficiency	efficiency ratio	relative efficiency	overall efficiency	relative efficiency
Compression ratio of I.C. engine is	the ratio of volumes of air in cylinder before compression stroke and after compression stroke.	volume displaced by piston per stroke and clearance volume in cylinder.	ratio of pressure after compression and before compression.	swept volume/cylinder volume.	the ratio of volumes of air in cylinder before compression stroke and after compression stroke.
The air standard efficiency of an otto cycle compared to diesel cycle for the given compression ratio is	same	less	more	more or less depending on power rating	more
The calorific value of gaseous fuels is expressed in terms of	Kcal	Kcal/kg	Kcal/m <sup>2</sup>	Kcal/m <sup>3</sup>	Kcal/m <sup>3</sup>
If the intake air temperature of I.C. engine increases its efficiency will	increase	decrease	remain same	none of the mentioned	decrease
All heat engines utilize	low heat value of oil	high heat value of oil	net calorific value of oil	calorific value of fuel	low heat value of oil
An engine indicator is used to determine the following	speed	temperature	volume of cylinder	m.e.p and I.H.P	m.e.p and I.H.P
Fuel oil consumption guarantees for I.C. engine are usually based on	low heat value of oil	high heat value of oil	net calorific value of oil	calorific value of fuel	high heat value of oil

The thermal efficiency of a diesel cycle having fixed compression ratio, with increase in cut-off ratio will	increase	decrease	be independent	none of the mentioned	decrease
The output of a diesel engine can be increased without increasing the engine revolution or size in following way	feeding more fuel	increasing flywheel size	heating incoming air	supercharging	supercharging
The air-fuel ratio of the petrol engine is controlled by	fuel pump	governor	carburettor	scavenging	carburettor
A 75 cc engine has following parameter as 75 cc	fuel tank capacity	lub oil capacity	swept volume	cylinder volume	swept volume
Which of the following is not an internal combustion engine	2-stroke petrol engine	Steam turbine	gas turbine	diesel engine	Steam turbine
The accunmulation of carbon in a cylinder results in increase of	clearance volume	volumetric efficiency	ignition time	effective compression ratio	effective compression ratio
The specific fuel consumption per BH power for a petrol engine is approximately	0.15 kg	0.25 kg	0.3kg	0.35 kg.	0.25 kg
Pick up the false statement	Thermal efficiency of diesel engine is about 34%	Diesel engines are compression ignition engines	High speed compression engines operate on dual combustion cycle	S.I. engines are quality- governed engines	S.I. engines are quality-governed engines
The air requirement of a petrol engine during starting compared to theoretical required for complete combustion is	more	loss	same	may be more or less depending on engine capacity	loss

The rating of a diesel engine, with increase in air-inlet temperature, will	increase linearly	decrease linearly	increase parabolically	decrease parabolically	decrease parabolically
Compression loss in I.C engines occurs due to	leaking piston rings	use of thick head gasket	increase in clearance volume caused by bearing- bushing wear	all of the above	all of the above
If one cylinder of a diesel engine receives more fuel than the others then	exhaust will be smoky	piston rings would stick into piston grooves	scavenging occurs	exhaust temperature will be high	scavenging occurs
Diesel fuel, compared to petrol is	less difficult to ignite	just about the same difficult to ignite	more difficult to ignite	highly ignitable	more difficult to ignite
For the same compression ratio	Otto cycle is more efficient than the Diesel	Diesel cycle is more efficient'than Otto	compression ratio has nothing to do with efficiency	which is more efficient would depend on engine capacity	Otto cycle is more efficient than the Diesel
When crude oil is heated, then which of the following hydrocarbon is given off first	kerosene	gasoline	paraffin	natural gas	natural gas
Most high speed compression engines operate on	Diesel cycle	Otto cycle	Dual combustion cycle	Carnot cycle	Dual combustion cycle
As a result of detonation in an I.C. engine, following parameter attains very high value	peak pressure	rate of rise of pressure	rate of rise of temperature	peak temperature	rate of rise of pressure
The process of breaking up or a liquid into fine droplets by spraying is called	vaporisation	carburetion	ionisation	atomisation	atomisation

Engine pistons 'are usually made of aluminum alloy because it	is lighter	wears less	absorbs shocks	is stronger	is lighter
The actual volume of fresh charge admitted in 4-stroke petrol engine is	equal to stroke volume	equal to stroke volume and clearance volume	less than stroke volume	more than stroke volume	less than stroke volume
Gaseous-fuel guarantees are based on	calorific value of oil	low heat value of oil	high heat value of oil	mean heat value of oil	low heat value of oil
The cam shaft of a four stroke I.C. engine running at 1500 rpm will run at	1500 rpm	750 rpm	3000 rpm	2400 rpm	750rpm
Polymerisation is a chemical process in which molecules of a compound become	larger	slowed down	smaller	liquid	larger
The fuel air ratio in a petrol engine fitted with suction carburetor, operating with dirty air filter as compared to clean filter will be	higher	lower	remain unaffected	unpredictable	higher
The operation of forcing additional air under pressure in the engine cylinder is known as	scavenging	turbulence	supercharging	pre-ignition	supercharging
Which of the following is false statement : Excess quantities of sulphur in diesel fuel are Objectionable because it may cause the following	piston ring and cylinder wear	formation of hard coating on piston skirts	oil sludge in the engine crank case	detonation	detonation
Supercharging is essential in	diesel engines	gas turbines	petrol engines	aircraft engines	aircraft engines
In a cycle, the spark lasts roughly for	0.1sec	0.001sec	1sec	0.01sec	0.001sec
The minimum cranking speed in case of petrol engine is about	half the operating speed	one-fourth of operating speed	operating speed	60-80 rpm	60-80 rpm
The magneto in an automobile is basically	transformer	d.c. generator	capacitor	a.c. generator	d.c. generator

The specific fuel consumption of a petrol engine compared to diesel engine of same H.P. is	same	more	less	less or more depending on operating conditions	more
Most high speed compression engines operate on	Otto cycle	Diesel cycle	Dual cycle	Carnot cycle	Dual cycle
In the crankcase method of scavenging, the air pressure is produced by	supercharger	centrifugal pump	natural aspirator	movement of engine piston	movement of engine piston
Which of the following is the lightest and most volatile liquid fuel	diesel	kerosene	fuel oil	gasoline	gasoline
Installation of supercharger on a four-cycle diesel engine can result in the following percentage increase in power	upto 25%	upto 35%	upto 50%	upto 100%.	upto 100%.
The following volume of air is required for consuming 1 liter of fuel by a four stroke engine	1 m3	5 m3	5-6 m3	9-10 m3	9-10 m3
The air-fuel ratio in petrol engines-is controlled by	controlling valve opening/closing	governing	injection	carburettion	carburettion
A 5 BHP engine running at full load would consume diesel of the order of	0.3 kg/hr	1 kg/hr	3 kg/hr	5 kg/hr	1 kg/hr

#### **UNIT-II**

# STEAM POWER CYCLES AND BOILERS

# Simple Carburetor:

The function of a carburetor is to vaporize the petrol (gasoline) by means of engine suction and to supply the required air and fuel (petrol) mixture to the engine cylinder. During the suction stroke, air flows from atmosphere into the cylinder. As the air passes through the enture, velocity of air increases and its pressure falls below the atmosphere. The pressure at the nozzle tip is also below the atmospheric pressure. The pressure on the fuel surface of the fuel tank is atmospheric. Due to which a pressure difference is created, which causes the flow of fuel through the fuel jet into the air stream. As the fuel and air pass ahead of the enture, the fuel gets vaporized and required uniform mixture is supplied to the engine.

The quantity of fuel supplied to the engine depends upon the opening of throttle valve which is governed by the governor.



The main parts of a simple carburetor are:

**Float chamber:** The level of fuel in the float chamber is maintained slightly below the tip of the nozzle. If the level of petrol is above then the petrol will run from the nozzle and drip from the carburetor. If the petrol level is kept low than the tip of the nozzle then part of pressure head is lost in lifting the petrol up to the tip of nozzle. Generally it is kept at 5mm from the level of petrol in the float chamber. The level of the fuel is kept constant with the help of float and needle valve. The needle valve closes the inlet supply from main tank if the level rises above the required level. If the level of fuel decreases then the needle valve opens the supply. Generally the fuel level is kept 5mm below the nozzle tip.

**Venturi:** When the mixture passes through the narrowest section its velocity increases and pressure falls below the atmospheric. As it passes through the divergent section, pressure increases again.

KARPAGAM ACADEMY OF HIGHER EDUCATION

# 15BEME501

**Throttle valve:** It controls the quantity of air and fuel mixture supplied to the engine through intake manifold and also the head under which the fuel flows. **Choke:** It provides an extra rich mixture during to the engine starting and in cold weather to warm up the engine. The choke valve is nearly closed during clod starting and warming. It creates a high vacuum near the fuel jet which causes flow of more fuel from the jet.



## **Diesel Pump and Injector system:**





# **Diesel knocking and detonation:**

We already know that if the delay period is long, a large amount of fuel will be injected and accumulated in the chamber. The auto ignition of this large amount of fuel may cause high rate of pressure rise and high maximum pressure which may cause knocking in diesel engines. A long delay period not only increases the amount of fuel injected by the moment of ignition, but also improve the homogeneity of the fuel air mixture and its chemical preparedness for explosion type self ignition similar to detonation in SI engines.

It is very instructive to compare the phenomenon of detonation is SI ensues with that of knocking in CI engines. There is no doubt that these two phenomena are fundamentally similar. Both are processes of auto ignition subject to the ignition time lag characteristic of the fuel air mixture. However, differences in the knocking phenomena of the SI engine and the CI engine should also be care fully be noted:

- In the SI engine, the detonation occurs near the end of combustion where as in the CI engine detonation occurs near the beginning of combustion as shown in fig. 6.10.
- 2. The detonation in the SI engine is of a homogeneous charge causing very high rate of pressure rise and very high maximum pressure. In the CI engine the fuel and air are in perfectly mixed and hence the rate of pressure rise is normally lower than that in the detonating part of the charge in the SI engine.
- 3. Since in the CI engine the fuel is injected in to the cylinder only at the end of the compression stroke there is no question of pre ignition or pre mature ignition as in the SI engine.
- 4. In the SI engine it is relatively easy to distinguish between knocking and nonknocking operation as the human ear easily find the distinction. However, in the case of the CI engine the normal ignition is itself by auto ignition and hence no CI engines have a sufficiently high rate of pressure rise per degree crank angle to cause audible noise. When such noise becomes excessive or there is excessive vibration in engine structure, in the opinion of the observer, the engine is sending to knock. It is clear that personal judgment is involved here. Thus in the CI engine there is no definite distinction between normal and knocking combustion. The maximum rate of pressure rise in the CI engine may reach as high as 10bar per crank degree angle.

It is most important to note that factors that tend to reduce detonation in the SI engine increase knocking in CI engine and vice versa because of the following reason. The detonation of knocking in the SI engine is due to simultaneous auto ignition of the last part of the charge. To eliminate detonation in the SI engine we want to prevent all together the auto ignition of the last part of the charge and therefore desire a long delay period and high self ignition temperature of the fuel. To eliminate knocking the CI engine we want to achieve auto ignitions early as possible therefore desire a short delay period and low self ignition temperature of the fuel. Table 6.2 gives the factors which reduce knocking in the SI and CI engines.

Sr. No.	Factors	SI Engine	CI Engine
1	Self ignition	High	Low
	temperature of fuel		
2	Time lag or delay	Long	Short
	period for fuel		
3	Compression ratio	Low	High
4	Inlet temperature	Low	High
5	Inlet pressure	Low	High
6	Combustion	Low	High
	chamber wall		
	temperature		
7	Speed	High	Low
8	Cylinder size	Small	Large

**Table**: Factors tending to reduce knocking in SI and CI engine

It is also clear from the table and discussion that a good CI engine fuel is a bad SI engine fuel and a good SI engine is bad CI engine fuel. In other words diesel oil has low self ignition temperature and short time lag where as petrol have high self ignition temperature and a long ignition lag. In terms of fuel rating diesel oil has high cetane number (40 - 60) and low octane number (about 30) and petrol has high octane number (80 - 90) and low cetane number (18).

# **Ignition System:**

Basically Convectional Ignition systems are of 2 types :

- (a) Battery or Coil Ignition System, and
- (b) Magneto Ignition System.

Both these conventional, ignition systems work on mutual electromagnetic induction principle.

Battery ignition system was generally used in 4-wheelers, but now-a-days it is more commonly used in 2-wheelers also (i.e. Button start, 2-wheelers like Pulsar, Kinetic Honda; Honda-Activa, Scooty, Fiero, etc.). In this case 6 V or 12 V batteries will supply necessary current in the primary winding. Magneto ignition system is mainly used in 2-wheelers, kick start engines. (Example, Bajaj Scooters, Boxer, Victor, Splendor, Passion, etc.). In this case magneto will produce and supply current to the primary winding. So in magneto ignition system magneto replaces the battery.

# Battery or Coil Ignition System

Figure shows line diagram of battery ignition system for a 4-cylinder petrol engine. It mainly consists of a 6 or 12 volt battery, ammeter, ignition switch, auto-transformer (step up transformer), contact breaker, capacitor, distributor rotor, distributor contact points, spark

```
KARPAGAM ACADEMY OF HIGHER EDUCATION
```

plugs, etc. Note that the Figure 4.1 shows the ignition system for 4-cylinder petrol engine, here there are 4-spark plugs and contact breaker cam has 4-corners. (If it is for 6-cylinder engine it will have 6-spark plugs and contact breaker cam will be a hexagon).

The ignition system is divided into 2-circuits :

i. **Primary Circuit :** It consists of 6 or 12 V battery, ammeter, ignition switch, primary winding it has 200-300 turns of 20 SWG (Sharps Wire Gauge) gauge wire, contact breaker, capacitor.



(ii) **Secondary Circuit :** It consists of secondary winding. Secondary **Ignition Systems** winding consists of about 21000 turns of 40 (S WG) gauge wire. Bottom end of which is connected to bottom end of primary and top end of secondary winding is connected to centre of distributor rotor. Distributor rotors rotate and make contacts with contact points and are connected to spark plugs which are fitted in cylinder heads (engine earth).

(iii) **Working :** When the ignition switch is closed and engine in cranked, as soon as the contact breaker closes, a low voltage current will flow through the primary winding. It is also to be noted that the contact beaker cam opens and closes the circuit 4-times (for 4 cylinders) in one revolution. When the contact breaker opens the contact, the magnetic field begins to collapse. Because of this collapsing magnetic field, current will be induced in the secondary winding. And because of more turns (@ 21000 turns) of secondary, voltage goes unto 28000-30000 volts. This high voltage current is brought to centre of the distributor rotor. Distributor rotor rotates and supplies this high voltage current to proper stark plug depending upon the engine firing order. When the high voltage current jumps the spark plug gap, it produces the spark and the charge is ignited-combustion starts-products of combustion expand and produce power. **Magneto Ignition System** In this case as shown, we can have rotating magneto with fixed coil or rotating coil with fixed magneto for producing and supplying current to primary, remaining arrangement is same as that of a battery ignition system.



Comparison between Battery and Magneto Ignition System

Battery Ignition	Magneto Ignition
Battery is a must.	No battery needed.
Battery supplies current in primary circuit.	Magneto produces the required current for primary circuit.
A good spark is available at low speed also.	During starting the quality of spark is poor due to slow speed.
Occupies more space.	Very much compact.
Recharging is a must in case battery gets discharged.	No such arrangement required.
Mostly employed in car and bus for which it is required to crank the engine.	Used on motorcycles, scooters, etc.
Battery maintenance is required.	No battery maintenance problems.

# **Lubrication System:**

Splash :



The splash system is no longer used in automotive engines. It is widely used in small four-cycle engines for lawn mowers, outboard marine operation, and so on. In the splash lubricating system, oil is splashed up from the oil pan or oil trays in the lower part of the crankcase. The oil is thrown upward as droplets or fine mist and provides adequate lubrication to valve mechanisms, piston pins, cylinder walls, and piston rings.

In the engine, dippers on the connecting-rod bearing caps enter the oil pan with each crankshaft revolution to produce the oil splash. A passage is drilled in each connecting rod from the dipper to the bearing to ensure lubrication. This system is too uncertain for automotive applications. One reason is that the level of oil in the crankcase will vary greatly the amount of lubrication received by the engine. A high level results in excess lubrication and oil consumption and a slightly low level results in inadequate lubrication and failure of the engine.

## **Combination Splash and Force Feed :**



In a combination splash and force feed, oil is delivered to some parts by means of splashing and other parts through oil passages under pressure from the oil pump. The oil from the pump enters the oil galleries. From the oil galleries, it flows to the main bearings and camshaft bearings. The main bearings have oil-feed holes or grooves that feed oil into drilled passages in the crankshaft. The oil flows through these passages to the connecting rod bearings. From there, on some engines, it flows through holes drilled in the connecting rods to the piston-pin bearings.

Cylinder walls are lubricated by splashing oil thrown off from the connecting-rod bearings. Some engines use small troughs under each connecting rod that are kept full by small nozzles which deliver oil under pressure from the oil pump. These oil nozzles deliver an increasingly heavy stream as speed increases. At very high speeds these oil streams are powerful enough to strike the dippers directly. This causes a much heavier splash so that adequate lubrication of the pistons and the connecting-rod bearings is provided at higher speeds. If a combination system is used on an overhead valve engine, the upper valve train is lubricated by pressure from the pump.

**Force Feed :** 



A somewhat more complete pressurization of lubrication is achieved in the force-feed lubrication system . Oil is forced by the oil pump from the crankcase to the main bearings and the camshaft bearings. Unlike the combination system the connecting-rod bearings are also fed oil under pressure from the pump.Oil passages are drilled in the crankshaft to lead oil to the connecting-rodbearings. The passages deliver oil from the main bearing journals to the rod bearing journals. In some engines, these opening are holes that line up once for every crankshaft revolution. In other engines, there are annular grooves in the main bearings through which oil can feed constantly into the hole in the crankshaft. The pressurized oil that lubricates the connecting-rod bearings goes on to lubricate the pistons and walls by squirting out through strategically drilled holes. This lubrication system is used in virtually all engines that are equipped with semifloating piston pins.

## **Full Force Feed:**

In a full force-feed lubrication system, the main bearings, rod bearings, camshaft bearings, and the complete valve mechanism are lubricated by oil under pressure. In addition, the full force-feed lubrication system provides lubrication under pressure to the pistons and the piston pins. This is accomplished by holes drilled the length of the connecting rod, creating an oil passage from the connecting rod bearing to the piston pin bearing. This passage not only feeds the piston pin bearings but also provides lubrication for the pistons and cylinder walls. This system is used in virtually all engines that are equipped with fullfloating piston pins.

## **Cooling System:**

## **Air Cooled System**

Air cooled system is generally used in small engines say up to 15-20 Kw and in aero plane engines.

In this system fins or extended surfaces are provided on the cylinder walls, cylinder head, etc. Heat generated due to combustion in the engine cylinder will be conducted to the fins and when the air flows over the fins, heat will be dissipated to air.

The amount of heat dissipated to air depends upon :

(a) Amount of air flowing through the fins.

(b) Fin surface area.

I Thermal conductivity of metal used for fins.



# Advantages of Air Cooled System

Following are the advantages of air cooled system :

(a) Radiator/pump is absent hence the system is light.

(b) In case of water cooling system there are leakages, but in this case there are no leakages.

I Coolant and antifreeze solutions are not required.

(d) This system can be used in cold climates, where if water is used it may freeze.

## **Disadvantages of Air Cooled System**

(a) Comparatively it is less efficient.

(b) It is used only in aero planes and motorcycle engines where the engines are exposed to air directly.

Water Cooling System: In this method, cooling water jackets are provided around the cylinder, cylinder head, valve seats etc. The water when circulated through the jackets, it absorbs heat of combustion. This hot water will then be cooling in the radiator partially

by a fan and partially by the flow developed by the forward motion of the vehicle. The cooled water is again recirculated through the water jackets

# **Types of Water Cooling System**

There are two types of water cooling system :

## **Thermo Siphon System**

In this system the circulation of water is due to difference in temperature (i.e. difference in densities) of water. So in this system pump is not required but water is circulated because of density difference only.



## **Pump Circulation System**

In this system circulation of water is obtained by a pump. This pump is driven by means of engine output shaft through V-belts.



## **Performance Calculation:**

Engine performance is an indication of the degree of success of the engine performs its assigned task, i.e. the conversion of the chemical energy contained in the fuel into the useful mechanical work. The performance of an engine is evaluated on the basis of the following : (a) Specific Fuel Consumption. (b) Brake Mean Effective Pressure. I Specific Power Output. (d) Specific Weight. (e) Exhaust Smoke and Other Emissions. The
particular application of the engine decides the relative importance of these performance parameters.

For Example : For an aircraft engine specific weight is more important whereas for an industrial engine specific fuel consumption is more important. For the evaluation of an engine performance few more parameters are chosen and the effect of various operating conditions, design concepts and modifications on these parameters are studied. The basic performance parameters are the following : (a) Power and Mechanical Efficiency. (b) Mean Effective Pressure and Torque. I Specific Output. (d) Volumetric Efficiency. (e) Fuel-air Ratio. (f) Specific Fuel Consumption. (g) Thermal Efficiency and Heat Balance. (h) Exhaust Smoke and Other Emissions. (i) Specific Weight.

## **Power and Mechanical Efficiency**

The main purpose of running an engine is to obtain mechanical power.

- Power is defined as the rate of doing work and is equal to the product of force and linear velocity or the product of torque and angular velocity.
- Thus, the measurement of power involves the measurement of force (or torque) as well as speed. The force or torque is measured with the help of a dynamometer and the speed by a tachometer. The power developed by an engine and measured at the output shaft is called the brake power (bp) and is given by

bp=2Πnt/60

where,

T is torque in N-m and

N is the rotational speed in revolutions per minute.

The total power developed by combustion of fuel in the combustion chamber is, however, more than the bp and is called indicated power (ip). Of the power developed by the engine, i.e. ip, some power is consumed in overcoming the friction between moving parts, some in the process of inducting the air and removing the products of combustion from the engine combustion chamber.

## **Indicated Power**

It is the power developed in the cylinder and thus, forms the basis of evaluation of combustion efficiency or the heat release in the cylinder. Where,

I.P= PmLANK/60

pm = Mean effective pressure, N/m2,

L = Length of the stroke, m,

A = Area of the piston, m2,

N = Rotational speed of the engine, rpm (It is N/2 for four stroke engine), and

k = Number of cylinders.

Thus, we see that for a given engine the power output can be measured in terms of mean effective pressure. The difference between the ip and bp is the indication of the power lost in the mechanical components of the engine (due to friction) and forms the basis of mechanical efficiency; which is defined as follows : Mechanical efficiency=bp/ip The difference between ip and bp is called friction power (fp). Fp = ip - bp Mechanical efficiency=b.p/(bp+fp)

## **Mean Effective Pressure and Torque**

Mean effective pressure is defined as a hypothetical/average pressure which is assumed to be acting on the piston throughout the power stroke. Therefore,

where,

Pm = Mean effective pressure, N/m2,

Ip = Indicated power, Watt,

L = Length of the stroke, m,

A = Area of the piston, m2,

N = Rotational speed of the engine, rpm (It is N/2 for four stroke engine), and

k = Number of cylinders.

If the mean effective pressure is based on bp it is called the brake mean effective pressure (Pm), and if based on ihp it is called indicated mean effective pressure (imep). Similarly, the friction mean effective pressure (fmep) can be defined as, fmep = imep – bmep

The torque is related to mean effective pressure by the relation

B.P=2Πnt/60 I.P=PmLANk/60 2Πnt/60=[bmep.A.L.(Nk/60)] or, T=(bmep.A.L.k)/2π

Thus, the torque and the mean effective pressure are related by the engine size. A large engine produces more torque for the same mean effective pressure. For this reason, torque is not the measure of the ability of an engine to utilize its displacement for producing power from fuel. It is the mean effective pressure which gives an indication of engine

displacement utilization for this conversion. Higher the mean effective pressure, higher will be the power developed by the engine for a given displacement. Again we see that the power of an engine is dependent on its size and speed. Therefore, it is not possible to compare engines on the basis of either power or torque. Mean effective pressure is the true indication of the relative performance of different engines.

## **Specific Output**

Specific output of an engine is defined as the brake power (output) per unit of piston displacement and is given by,

Specific output=B.P/A.L

 $Constant = bmep \times rpm$ 

- The specific output consists of two elements the bmep (force) available to work and the speed with which it is working.
- Therefore, for the same piston displacement and bmep an engine operating at higher speed will give more output.
- It is clear that the output of an engine can be increased by increasing either speed or bmep. Increasing speed involves increase in the mechanical stress of various engine parts whereas increasing bmep requires better heat release and more load on engine cylinder.

## Volumetric Efficiency

Volumetric efficiency of an engine is an indication of the measure of the degree to which the engine fills its swept volume. It is defined as the ratio of the mass of air inducted into the engine cylinder during the suction stroke to the mass of the air corresponding to the swept volume of the engine at atmospheric pressure and temperature. Alternatively, it can be defined as the ratio of the actual volume inhaled during suction stroke measured at intake conditions to the swept volume of the piston.

Volumetric efficiency, hv = Mass of charge actually sucked in /Mass of charge corresponding . to the cylinder intake

The amount of air taken inside the cylinder is dependent on the volumetric efficiency of an engine and hence puts a limit on the amount of fuel which can be efficiently burned and the power output. For supercharged engine the volumetric efficiency has no meaning as it comes out to be more than unity.

## Fuel-Air Ratio (F/A)

Fuel-air ratio (F/A) is the ratio of the mass of fuel to the mass of air in the fuel-air mixture. Air-fuel ratio (A/F) is reciprocal of fuel-air ratio. Fuel-air ratio of the mixture affects the combustion phenomenon in that it determines the flame propagation velocity, the heat release in the combustion chamber, the maximum temperature and the completeness of combustion. Relative fuel-air ratio is defined as the ratio of the actual fuel-air ratio to that of the stoichiometric fuel-air ratio required to burn the fuel supplied. Stoichiometric fuel-air ratio is the ratio of fuel to air is one in which case fuel is completely burned due to minimum quantity of air supplied. Relative fuel-air ratio, =(Actual Fuel- Air ratio)/(Stoichiometric fuel-Air ratio)

#### **Brake Specific Fuel Consumption**

Specific fuel consumption is defined as the amount of fuel consumed for each unit of brake power developed per hour. It is a clear indication of the efficiency with which the engine develops power from fuel.

B.S.F.C= Relative fuel-air ratio, =(Actual Fuel- Air ratio)/(Stoichiometric fuel-Air ratio)

This parameter is widely used to compare the performance of different engines.

## **Thermal Efficiency and Heat Balance**

Thermal efficiency of an engine is defined as the ratio of the output to that of the chemical energy input in the form of fuel supply. It may be based on brake or indicated output. It is the true indication of the efficiency with which the chemical energy of fuel (input) is converted into mechanical work. Thermal efficiency also accounts for combustion efficiency, i.e., for the fact that whole of the chemical energy of the fuel is not converted into heat energy during combustion.

Brake thermal efficiency =  $B.P/mf^*$  Cv

where,

Cv = Calorific value of fuel, Kj/kg, and

mf = Mass of fuel supplied, kg/sec.

- The energy input to the engine goes out in various forms a part is in the form of brake output, a part into exhaust, and the rest is taken by cooling water and the lubricating oil.
- The break-up of the total energy input into these different parts is called the heat balance.
- The main components in a heat balance are brake output, coolant losses, heat going to exhaust, radiation and other losses.
- Preparation of heat balance sheet gives us an idea about the amount of energy wasted in various parts and allows us to think of methods to reduce the losses so incurred.

## **Exhaust Smoke and Other Emissions:**

Smoke and other exhaust emissions such as oxides of nitrogen, unburned hydrocarbons, etc. are nuisance for the public environment. With increasing emphasis on air pollution control all efforts are being made to keep them as minimum as it could be. Smoke is an indication of incomplete combustion. It limits the output of an engine if air pollution control is the consideration.

**Emission Formation Mechanisms: (S.I)** This section discusses the formation of HC, CO, Nox, CO2, and aldehydes and explains the effects of design parameters.

## i. Hydrocarbon Emissions

HC emissions are various compounds of hydrogen, carbon, and sometimes oxygen. They are burned or partially burned fuel and/or oil. HC emissions contribute to photochemical smog, ozone, and eye irritation. There are several formation mechanisms for HC, and it is convenient to think about ways HC can avoid combustion and ways HC can be removed; we will discuss each below. Of course, most of the HC input is fuel, and most of it

```
KARPAGAM ACADEMY OF HIGHER EDUCATION
```

is burned during "normal" combustion. However, some HC avoids oxidation during this process. The processes by which fuel compounds escape burning during normal S.I. combustion are:

- 1. Fuel vapor-air mixture is compressed into the combustion chamber crevice volumes.
- 2. Fuel compounds are absorbed into oil layers on the cylinder liner.
- 3. Fuel is absorbed by and/or contained within deposits on the piston head and piston crown. 4. Quench layers on the combustion chamber wall are left as the flame extinguishes close to the walls.
- 4. Fuel vapor-air mixture can be left unburned if the flame extinguishes before reaching the walls.
- 5. Liquid fuel within the cylinder may not evaporate and mix with sufficient air to burn prior to the end of combustion.
- 6. The mixture may leak through the exhaust valve seat.

#### (ii) Carbon Monoxide

Formation of CO is well established. Under some conditions, there is not enough O2 available for complete oxidation and some of the carbon in the fuel ends up as CO. The amount of CO, for a range of fuel composition and C/H ratios, is a function of the relative airfuel ratio. Even when enough oxygen is present, high peak temperatures can cause dissociation – chemical combustion reactions in which carbon dioxide and water vapor separate into CO, H2, and O2. Conversion of CO to CO2 is governed by reaction CO + OH  $\leftrightarrow$  CO2 + H Dissociated CO may freeze during the expansion stroke.

#### (iii) Oxides of Nitrogen

Nox is a generic term for the compounds NO and NO2. Both are present to some degree in the exhaust, and NO oxidizes to NO2 in the atmosphere. Nox contributes to acid rain and photochemical smog; it is also thought to cause respiratory health problems at atmospheric concentrations found in some parts of the world. To understand Nox formation, we must recognize several factors that affect Nox equilibrium. Remember that all chemical reactions proceed toward equilibrium at some reaction rate. Equilibrium NO (which comprises most of the Nox formation) is formed at a rate that varies strongly with temperature and equivalence ratio.

#### (iv) Carbon Dioxide

While not normally considered a pollutant, CO2 may contribute to the greenhouse effect. Proposals to reduce CO2 emissions have been made. CO2 controls strongly influence fuel economy requirements.

#### (v) Aldehydes

Aldehydes are the result of partial oxidation of alcohols. They are not usually present in significant quantities in gasoline-fueled engines, but they are an issue when alcohol fuels are used. Aldehydes are thought to cause lung problems. So far, little information of engine calibration effects on aldehyde formation is available.

**Emission Formation In C.I. Engine** 

```
KARPAGAM ACADEMY OF HIGHER EDUCATION
```

For many years, diesel engines have had a reputation of giving poor performance and producing black smoke, an unpleasant odor, and considerable noise. However, it would find it difficult to distinguish today"s modern diesel car from its gasoline counterpart. For diesel engines the emphasis is to reduce emissions of Nox and particulates, where these emissions are typically higher than those from equivalent port injected gasoline engines equipped with three-way catalysts. Catalyst of diesel exhaust remains a problem insofar as researchhas not yet been able to come up with an effective converter that eliminates both particulate matter (PM) and oxide of nitrogen (Nox).

## **Principle C.I. Engine Exhaust Constituents**

For many years, diesel engines have had a reputation of giving poor performance and producing black smoke, an unpleasant odor, and considerable noise. However, it would find it difficult to distinguish today''s modern diesel car from its gasoline counterpart. Concerning CO and HC emissions, diesel engines have an inherent advantages, therefore the emphasis is to reduce emissions of Nox and particulates, where these emissions are typically higher than those from equivalent port injected gasoline engines equipped with three-way catalysts. Catalyst of diesel exhaust remains a problem insofar as research has not yet been able to come up with an effective converter that eliminates both particulate matter (PM) and oxide of nitrogen (Nox). In the same manner as with SI engines, the air/fuel ratio of the diesel engine has a significant impact on the level of pollutant concentrations but this parameter is not freely available for minimizing pollution.

#### **Problems:**

To determine Brake power, Indicated Power, Frictional Power, Brake Thermal Efficiency, Indicated Thermal Efficiency, Mechanical Efficiency, Relative Efficiency, Volumetric Efficiency, Brake Specific Fuel Consumption, Indicated Specific Fuel Consumption, Indicated mean effective pressure, Brake mean effective pressure.

KARPAGAM ACADEMY OF HIGHER EDUCATION

#### Sample problems:

1. Following data relates to 4 cylinder, single stroke petrol engine. A/F ratio by weight 16:1. Calorific value of the fuel= 45200 Kj/kg, mechanical efficiency=82%. Air standard efficiency=52%, relative efficiency=70%, volumetric efficiency=78%, L/D=1.25, suction condition=1 bar, 250C. Speed=2400 rpm and power at brakes=72kw. Calculate

- 1. Compression ratio
- 2. Indicated Thermal Efficiency
- 3. Brake specific fuel consumption
- 4. Bore and Stroke.

2.A six cylinder, 4 stroke SI engine having a piston displacement of 700cm3 per cylinder developed 78Kw at 3200 rpm and consumed 27 kg of petrol per hour. The calorific value of the fuel is 44MJ/kg. Estimate

1. The volumetric efficiency of the engine if the air-fuel ratio is 12 and intake air is at 0.9 bar, 32 oC.

2.Brake thermal efficiency and brake torque. For air R=0.287 Kj/kgK.

# MULTIPLE CHOICE QUESTIONS:

Questions	opt1	opt2	opt3	opt4	answer
The equivalent evaporation of a boiler is a measure to compare	the given boiler with the model	the two different boilers of the same make	two different makes of boilers operating under the same operating conditions	any type of boilers operating under any conditions	any type of boilers operating under any conditions
Heating of dry steam above saturation temperature is known as	enthalpy	superheating	supersaturation	latent heat	superheating
Superheating of steam is done at	constant volume	constant temperature	constant pressure constant entropy		constant pressure
The saturation temperature of steam with increase in pressure increases	linearly	rapidly first and then slowly	slowly first and then rapidly	inversely	rapidly first and then slowly
1 kg.m is equal to	9.81 Joules	All Joules	427 Joules	102 Joules	9.81 Joules
One kg of steam sample contains 0.8 kg dry steam; it's dryness fraction is	0.2	0.8	1.5	2	0.8
A wet vapour can be completely specified by	pressure only	temperature only	dryness fraction only	pressure and dryness fraction	pressure and dryness fraction
Sublimation region is the region where	solid and vapour phases are in equilibrium	solid and liquid phases are in equilibrium	liquid and vapour phases are in equilibrium	solid, liquid and vapour phases are in equilibrium	solid and vapour phases are in equilibrium

Fire tube boilers are those in which	Water passes through the tubes and flue gases surround them	Tubes are laid vertically.	Forced circulation takes place.	Flue gases pass through tubes and water surrounds them.	Flue gases pass through tubes and water surrounds them.
What is the basic purpose of a drum in a boiler?	To remove salt from water.	To serve as a storage of steam.	To separate steam from water	All of these	To separate steam from water
In a boiler a blow off cock is used to	Blow air into the furnace.	Allow flue gases to escape to the chimney.	Drain off water resulting from partial condensation of steam.	Remove sludge from the boiler	Remove sludge from the boiler
The size of boiler tubes is specified by	Outside diameter and inside diameter.	Mean diameter and thickness.	Outside diameter and thickness.	Inside diameter and thickness.	Outside diameter and thickness.
Blow down from the boiler drum is carried out to	Lower steam pressure.	Increase steam temperature.	Control the solids concentration in boiler water.	All of the above.	Control the solids concentration in boiler water.
The economiser unit of a boiler is located between	Super heater and air preheater.	Air preheater and chimney.	Forced draught fan and furnace.	Furnace and super heater.	Super heater and air preheater.
Locomotive boiler is a	Single tube, vertical, externally fired and stationery boiler.	Single tube, horizontal, internally fired and stationery boiler.	Multi-tubular, horizontal, internally fired and mobile boiler.	Multi-tubular, horizontal, externally fired and stationary boiler.	Multi-tubular, horizontal, internally fired and mobile boiler.

The power of induced draught fan as compared to forced draught fan is for the same draught.	Less.	More.	Same.	Not predictable.	More.
The pressure at the furnace is minimum in case of	Natural draught system.	Balanced draught system.	Induced draught system.	Forced draught system.	Balanced draught system.
The amount of water evaporated in kg per kg of fuel burnt is called	Evaporating capacity of a boiler.	Equivalent evaporation from and at 100°C.	Boiler efficiency.None of these.Polytropic.Hyperbolic.		Evaporating capacity of a boiler.
In Rankine cycle the expansion of steam is assumed to be	Isothermal.	Adiabatic.	Polytropic.	Hyperbolic.	Adiabatic.
In a flow through a nozzle the mach number is more than unity	At the throat.	In the converging.	In the diverging section.	None of these.	In the diverging section.
Which of the following aspects is invalid for a convergent-divergent nozzle?	Supersonic flow in the divergent portion.	Subsonic flow in convergent portion.	Velocity of flow equals sonic velocity at the throat.	Flow may reverse back from supersonic to subsonic value towards the nozzle exit.	Flow may reverse back from supersonic to subsonic value towards the nozzle exit.
In a nozzle the effect of super saturation is	To increase the entropy.	To increase the heat drop.	To decrease dryness fraction of steam.	To decrease specific volume of steam	To increase the entropy.
A wet vapour can be completely specified by	pressure only	temperature only	dryness fraction only	pressure and dryness fraction	pressure and dryness fraction

## 15BEME501

Sublimation region is the region where	solid and vapour phases are in equilibrium	solid and liquid phases are in equilibrium	solid, liquid and vapour phases are in equilibrium	liquid and vapour phases are in equilibrium	solid and vapour phases are in equilibrium
If a steam sample is nearly in dry condition, then its dryness fraction can be most accurately determined by	throttling calorimeter	separating calorimeter	combined separating and throttling calorimeter	bucket calorimeter	throttling calorimeter
What is the unit of Heat?	W	KW/kJ	kJ	KW	kJ
Rankine cycle operating on low pressure limit of p1 and high pressure limit of p2	has higher thermal efficiency than the Carnot cycle operating between same pressure limits	has lower thermal efficiency than Carnot cycle operating between same pressure limits	has same thermal efficiency as Carnot cycle operating between same pressure limits	may be more or less depending upon the magnitudes of p1 and p2	has higher thermal efficiency than the Carnot cycle operating between same pressure limits
Rankine efficiency of a Steam Power Plant	improves in Summer as compared to that in Winter	improves in Winter as compared to that in Summer	is unaffected by climatic conditions	none of the mentioned	improves in Winter as compared to that in Summer
Rankine cycle comprises of	two isentropic processes and two constant volume processes	two isentropic processes and two constant pressure processes	two isothermal processes and two constant pressure processes	none of the mentioned	two isentropic processes and two constant pressure processes

In Rankine cycle, the work output from the turbine is given by	change of internal energy between inlet and outlet	change of enthalpy between inlet and outlet	change of entropy between inlet and outlet	change of temperature between inlet and outlet	change of enthalpy between inlet and outlet
Which of the following contributes to the improvement of efficiency of Rankine cycle in a Thermal Power Plant?	reheating of steam at intermediate stage	regeneration use of steam for heating Boiler feed water	use of high pressures	all of the mentioned	all of the mentioned
What is the actual turbine inlet temperature in Rankine cycle?	700C	800C	550C	1150C	550C
Rankine cycle efficiency of a good Steam Power Plant may be in the range of?	15 to 20%	35 to 45%	70 to 80%	90 to 95%	35 to 45%
A simple Rankine cycle operates the Boiler at 3 MPa with an outlet temperature of 350°C and the Condenser at 50 kPa. Assuming ideal operation and processes, what is the thermal efficiency of this cycle?	7.7	17.7	27.7	37.7	27.7
A simple Rankine cycle produces 40 MW of power, 50 MW of process heat and rejects 60 MW of heat to the surroundings. What is the utilization factor of this co generation cycle neglecting the pump work?	50	60	80	90	60

Evaporation type of condenser has	Water in pipes surrounded by steam.	Steam in pipes surrounded by water.	Either of the above.	None of the above.	Steam in pipes surrounded by water.
In a shell and tube surface condenser	Steam passes through the cooling tubes and cooling water surrounds them.	Cooling water passes through the tubes and steam surrounds them.	Steam and cooling water mix to give the condensate.	All the above varying with situation.	Cooling water passes through the tubes and steam surrounds them.
In jet type condensers	Cooling water passes through tubes and steam surrounds them.	Steam passes through tubes and cooling water surrounds them.	Steam and cooling water mix.	Steam and cooling water do not mix.	Steam and cooling water mix.
What is the purpose of reheating of steam in a turbine?	It reduces wear on blade.	It increases the efficiency of the turbine.	It increases the work done through the turbine.	All of these.	All of these.
The effect of bleeding is	The boiler is supplied with hot water.	It increases the thermodynamic efficiency of the turbine.	It decreases the power developed by the turbine.	All of these.	All of these.
The steam turbines are governed to	Completely balance.	Reduce effective heat drop.	Maintain the speed of the turbine.	Reheat steam and improve its quality.	Maintain the speed of the turbine.

is an essential merit of a reaction turbine.	Greater work output.	Capability to have expansions in stages.	High diagram efficiency.	Blade speeds lie in the useful range.	Blade speeds lie in the useful range.
In steam turbines the reheat factor	Remains same irrespective of number of stages.	Decreases with the increase in number of stages.	Increases with the increase in number of stages.	None of these.	Increases with the increase in number of stages.
Reheat factor in steam turbines depends on	Stage efficiency only.	Exit pressure only.	Initial pressure and temperature only.	All of these.	All of these.
The degree of reaction is for Parson's reaction steam turbine.	50%	100%	60%	75%	50%

#### UNIT-III STEAM NOZZLES AND TURBINES

#### Flow of steam through nozzles :

The flow of steam through nozzles may be regarded as adiabatic expansion. The steam has a very high velocity at the end of the expansion, and the enthalpy decreases as expansion takes place.Friction exists between the steam and the sides of the nozzle; heat is produced as the result of the resistance to the flow. The phenomenon of supersaturation occurs in the flow of steam through nozzles. This is due to the time lag in the condensation of the steam during the expansion.

#### Continuity and steady flow energy equations

Through a certain section of the nozzle:

m.v = A.C

m is the mass flow rate, v is the specific volume, A is the cross-sectional area and C is the velocity. For steady flow of steam through a certain apparatus, principle of conservation of energy states:

h1 + C12/2 + gz1 + q = h2 + C22/2 + gz2 + w

For nozzles, changes in potential energies are negligible, w = 0 and  $q \approx 0$ . H1 + C12 /2 = h2 + C22 /2 **Types of Nozzles:** 

- 1. Convergent Nozzle
- 2. Divergent Nozzle
- 3. Convergent-Divergent Nozzle

## **Convergent Nozzle**

A typical convergent nozzle is shown in the Fig.16.1. In a convergent nozzle, the cross sectional area decreases continuously from its entrance to exit. It is used in a case where the back pressure is equal to or greater than the



critical pressure ratio (which will be defined later).

## **Divergent nozzle**

The cross sectional area of divergent nozzle increases continuously from its entrance to exit. It is used in a case where the back pressure is less than the critical pressure ratio.



## **Convergent-Divergent Nozzle**

In this case, the cross sectional area first decreases from its entrance to throat and then increases from throat to exit. This case is also used in the case where the back pressure is less than the critical pressure. Also, in present day application, it is widely used in many types of steam turbines.



#### Supersaturated flow or Metastable flow in Nozzles:

As steam expands in the nozzle, its pressure and temperature drop, and it is expected that the steam start condensing when it strikes the saturation line. But this is not always the case. Owing to the high velocities, the residence time of the steam in the nozzle is small, and there may not sufficient time for the necessary heat transfer and the formation of liquid droplets. Consequently, the condensation of steam is delayed for a little while. This phenomenon is known as supersaturation, and the steam that exists in the wet region without containing any liquid is known as supersaturated steam. The locus of points where condensation will take place regardless of the initial temperature and pressure at the nozzle entrance is called the Wilson line. The Wilson line lies between 4 and 5 percent moisture

curves in the saturation region on the h-s diagram for steam, and is often approximated by the 4 percent moisture line. The supersaturation phenomenon is shown on the h-s chart below



The *h*-*s* diagram for the isentropic expansion of steam in a nozzle.

## **Effects of Supersaturation:**

The following are the effects of supersaturation in a nozzle.

- (a) The temperature at which the supersaturation occurs will be less than the saturation temperature corresponding to that pressure. Therefore, the density of supersaturated steam will be more than that of equilibrium condition which gives the increase in the mass of steam discharged.
- (b) Supersaturation increases the specific volume and entropy of the steam.
- (c) Supersaturation reduces the heat drop. Thus the exit velocity of steam is reduced.
- (d) Supersaturation increases the dryness fraction of the steam.

**Critical Pressure Ratio:** The critical pressure ratio is the pressure ratio which will accelerate the flow to a velocity equal to the local velocity of sound in the fluid. **Critical flow nozzles** are also called **sonic chokes**. By establishing a shock wave the sonic choke establish a fixed flow rate unaffected by the differential pressure, any fluctuations or changes in downstream pressure. A sonic choke may provide a simple way to regulate a gas flow.



The ratio between the critical pressure and the initial pressure for a nozzle can expressed as pc / p1 = (2 / (n + 1))n / (n - 1)

where pc = critical pressure (Pa) p1 = inlet pressure (Pa) n = index of isentropic expansion or compression – or polytropic constant

For a perfect gas undergoing an adiabatic process the index -n - is the ratio of specific heats -k = cp / cv.

There is no unique value for – n. Values for some common gases are

- Steam where most of the process occurs in the wet region : n = 1.135
- Steam superheated : n = 1.30
- Air : n = 1.4
- Methane : n = 1.31
- Helium : n = 1.667

## **Effect of Friction on Nozzles:**

- 1) Entropy is increased.
- 2) Available energy is decreased.
- 3) Velocity of flow at throat is decreased.
- 4) Volume of flowing steam is decreased.
- 5) Throat area necessary to discharge a given mass of steam is increased

Most of the friction occurs in the diverging part of a convergentdivergent nozzle as the length of the converging part is very small. The effect of friction is to reduce the available enthalpy drop by about 10 to 15 per cent. The velocity of steam will be then  $V_2 = 44.72\sqrt{K(H_1 - H_2)}$  where K is the coefficient which allows for friction loss. It is also known as nozzle efficiency  $(\eta_n)$ 

:. 
$$V_2 = 44.72\sqrt{(H_1 - H_2)\eta_n}$$



Velocity of steam at nozzle exit:

$$V_2^2 = 2000(H_1 - H_2) + V_1^2$$
  $\therefore$   $V_2 = \sqrt{2000(H_1 - H_2) + V_1^2}$ 

As the velocity of steam entering the nozzle is very small,  $V_1$  can be neglected.

:. 
$$V_2 = \sqrt{2000(H_1 - H_2)} = 44.72\sqrt{(H_1 - H_2)}$$
 m/s

· If frictional losses are taken into account then

$$V_2 = 44.72\sqrt{(H_1 - H_2)\eta_n}$$
 m/s

Mass of steam discharged through a nozzle:

$$m = A \sqrt{2000 \frac{n}{n-1} \times \frac{P_1}{\nu_1} \left[ \left( \frac{P_2}{P_1} \right)^{\frac{2}{n}} - \left( \frac{P_2}{P_1} \right)^{\frac{n+1}{n}} \right]}$$

Condition for maximum discharge through nozzle:

$$\frac{m}{A} = \sqrt{2000 \frac{n}{n-1} \times \frac{P_1}{\nu_1} \left[ \left( \frac{P_2}{P_1} \right)^{\frac{2}{n}} - \left( \frac{P_2}{P_1} \right)^{\frac{n+1}{n}} \right]}$$

The mass flow per unit area will be maximum at the throat because the throat area is minimum.

It is seen from the above equation that the discharge through a nozzle is a function of  $\frac{P_2}{P_1}$  only, as the expansion index is fixed according to the steam supplied to the nozzle.

Therefore,  $\frac{m}{4}$  is maximum when

$$\left[\left(\frac{P_2}{P_1}\right)^{\frac{2}{n}} - \left(\frac{P_2}{P_1}\right)^{\frac{n+1}{n}}\right]$$
 is minimum

Values for maximum discharge:

$$=A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \times \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}} \left[\left(\frac{2}{n+1}\right)^{\frac{1-n}{n-1}} - 1\right]}$$

$$=A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \times \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}} \left[\left(\frac{2}{n+1}\right)^{-1} - 1\right]}$$

$$=A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \times \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}} \left[\frac{n+1}{2} - 1\right]}$$

$$=A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \times \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}} \left[\frac{n-1}{2}\right]}$$

$$m_{\max} = A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \times \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}}}$$

$$m = A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \left[\left(\frac{P_{2}}{P_{1}}\right)^{\frac{2}{n}} - \left(\frac{P_{2}}{P_{1}}\right)^{\frac{n+1}{n-1}}\right]}$$
we know  $\frac{P_{2}}{P_{1}} = \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}}$ 
Putting the value of  $\frac{P_{2}}{P_{1}}$  in the above equation
$$m_{\max} = A\sqrt{2000\frac{n}{n-1} \times \frac{P_{1}}{v_{1}} \left[\left(\frac{2}{n+1}\right)^{\frac{2}{n-1}} - \left(\frac{2}{n+1}\right)^{\frac{n+1}{n-1}} - 1\right]}$$

Where P1 is the initial pressure of the steam in kpa and v1 is the specific volume of the steam in m3/kg at the initial pressure.

#### **STEAM TURBINES:**

Normally the turbines are classified into types,

- 1. Impulse Turbine
- 2. Reaction Turbine

#### **Impulse and Reaction Turbines:**



**Impulse Turbines** The steam jets are directed at the turbine"s bucket shaped rotor blades where the pressure exerted by the jets causes the rotor to rotate and the velocity of the steam to reduce as it imparts its kinetic energy to the blades. The blades in turn change change the direction of flow of the steam however its pressure remains constant as it passes through the rotor blades since the cross section of the chamber between the blades is constant. Impulse turbines are therefore also known as constant pressure turbines. The next series of fixed blades reverses the direction of the steam before it passes to the second row of moving blades.

**Reaction Turbines** The rotor blades of the reaction turbine are shaped more like aerofoils, arranged such that the cross section of the chambers formed between the fixed blades diminishes from the inlet side towards the exhaust side of the blades. The chambers between the rotor blades essentially form nozzles so that as the steam progresses through the chambers its velocity increases while at the same time its pressure decreases, just as in the nozzles formed by the fixed blades. Thus the pressure decreases in both the fixed and moving blades. As the steam emerges in a jet from between the rotor blades, it creates a reactive force on the blades which in turn creates the turning moment on the turbine rotor, just as in Hero<sup>\*</sup>s

steam engine. (Newton"s Third Law – For every action there is an equal and opposite reaction)



#### **Compounding of impulse turbine :**

This is done to reduce the rotational speed of the impulse turbine to practical limits. (A rotor speed of 30,000 rpm is possible, which is pretty high for practical uses.) Compounding is achieved by using more than one set of nozzles, blades, rotors, in a series, keyed to a common shaft; so that either the steam pressure or the jet velocity is absorbed by the turbine in stages. Three main types of compounded impulse turbines are: a) Pressure compounded, b) velocity compounded and c) pressure and velocity compounded impulse turbines.

#### **1. Velocity Compounding:**

The velocity-compounded impulse turbine was first proposed by C.G. Curtis to solve the problems of a single-stage impulse turbine for use with high pressure and temperature steam. The Curtis stage turbine, as it came to be called, is composed of one stage of nozzles as the single-stage turbine, followed by two rows of moving blades instead of one. These two rows are separated by one row of fixed blades attached to the turbine stator, which has the function of redirecting the steam leaving the first row of moving blades to the second row of moving blades. A Curtis stage impulse turbine is shown in Fig. with schematic pressure and absolute steam-velocity changes through the stage. In the Curtis stage, the total enthalpy drop and hence pressure drop occur in the nozzles so that the pressure remains constant in all three rows of blades.



Pi = Inlet Pressure Pe= Exit Pressure

Vi=Inlet Velocity Ve=Exit Velocity

## 2. Pressure Compounding:

This involves splitting up of the whole pressure drop from the steam chest pressure to the condenser pressure into a series of smaller pressure drops across several stages of impulse turbine. -The nozzles are fitted into a diaphragm locked in the casing. This diaphragm separates one wheel chamber from another. All rotors are mounted on the same shaft and the blades are attached on the rotor.



## 2. Pressure-Velocity Compounding :

A two-row velocity compounded turbine is found to be more efficient than the three-row type. In a two-step pressure velocity compounded turbine, the first pressure drop occurs in the first set of nozzles, the resulting gain in the kinetic energy is absorbed successively in two rows of moving blades before the second pressure drop occurs in the second set of nozzles. Since the kinetic energy gained in each step is absorbed completely before the next pressure drop, the turbine is pressure compounded and as well as velocity compounded. The kinetic energy gained due to the second pressure drop in the second set of nozzles is absorbed successively in the two rows of moving blades. The pressure velocity compounded steam turbine is comparatively simple in construction and is much more compact than the pressure compounded turbine





This is a combination of pressure and velocity compounding

## **Reaction Turbine:**

A reaction turbine, therefore, is one that is constructed of rows of fixed and rows of moving blades. The fixed blades act as nozzles. The moving blades move as a result of the impulse of steam received (caused by change in momentum) and also as a result of expansion and acceleration of the steam relative to them. In other words, they also act as nozzles. The enthalpy drop per stage of one row fixed and one row moving blades is divided among them, often equally. Thus a blade with a 50 percent degree of reaction, or a 50 percent reaction stage, is one in which half the enthalpy drop of the stage occurs in the fixed blades and half in the moving blades. The pressure drops will not be equal, however. They are greater for the fixed blades and greater for the high-pressure than the low-pressure stages. The moving blades of a reaction turbine are easily distinguishable from those of an impulse turbine in that they are not symmetrical and, because they act partly as nozzles, have a shape similar to that of the fixed blades, although curved in the opposite direction. The schematic pressure line in figure shows that pressure continuously drops through all rows of blades, fixed and moving. The absolute steam velocity changes within each stage as shown and repeats from stage to stage. The second figure shows a typical velocity diagram for the reaction stage.



Pressure and enthalpy drop both in the fixed blade or **stator** and in the moving blade or **Rotor** 

## **Governing of Steam Turbine:**

The method of maintaining the turbine speed constant irrespective of the load is known as governing of turbines. The device used for governing of turbines is called Governor. There are 3 types of governors in steam turbine,

- 1. Throttle governing
- 2. Nozzle governing

3. By-pass governing

## **1.Throttle Governing:**



Let us consider an instant when the load on the turbine increases. As a result the speed of the turbine decreases. The fly balls of the governor will come down. The fly balls bring down the sleeve. The downword movement of the sleeve will raise the control valve rod. The mouth of the pipe AA will open. Now the oil under pressure will rush from the control valve to the right side of the piston in the relay cylinder through the pipe AA. This will move the piston and spear towards the left which will open more area of nozzle. As a result the steam flow rate into the turbine increases, which inturn brings the speed of the turbine to the normal range.

2.Nozzle Governing:

A diagrammatic arrangement of nozzle control governing is shown in Fig. In this nozzles are grouped together in 3 to 5 or more groups and each group of nozzle is supplied steam controlled by valves. The arc of admission is limited to 180° or less. The nozzle control governing is restricted to the first stage of the turbine, the nozzle area in other stages remaining constant. It is suitable for the simple impulse turbine and for larger units which have an impulse stage followed by an impulse reaction turbine.

## **Bypass Governing**

The high pressure impulse turbines generally have a number of stages of small mean diameter of wheel. These turbines are generally designed for maximum efficiency at an economic load which is about 80 per cent of the maximum continuous rating. Due to the small heat drop in the first stage nozzle control governing cannot be efficiently used. Secondly it is desirable to have full admission into high pressure stage at the rated economic load to eliminate the partial admission losses.

In such cases bypass governing is used.

In this arrangement for high loads a bypass line is provided for the steam from the first stage nozzle box into a later stage where work output increases. The bypass of steam is automatically regulated by the lift of the valve. The bypass valve is under the control of the speed of the governor for all loads within its range. In later stages though there is increase in work output, the efficiency is low due to throttling effect.



## Sample Problems on Steam Nozzle:

1.Steam at pressure of 1.5 Mpa and temperature of 260oC expands isentropically in a steam nozzle to a pressure 500 kPa with an actual enthalpy drop of 200 Kj/kg. If the nozzle outlet area is approximately 4 cm2 and mass flow rate is 10 kg/s, calculate the number of nozzles required and adjust the outlet dimensions to suit this number.

2.Dry saturated steam at 10 bar pressure enters a convergent nozzle which is having 10mm throat diameter and 12 mm divergent portion length. Determine the diameter at the nozzle exit and cone angle of the divergent portion so that the steam may leave at 1 bar pressure. Assume the effects of Friction are negligible.

3.Steam at pressure of 22 bar and temperature 300oC is supplied to a group of five nozzles at the rate of 4.5 kg/s. The exit pressure of steam is 3 bar. Determine the following: i. The dimensions of the nozzles of rectangular cross section with an aspect ratio of 3:1. Neglect the friction effect and assume the expansion is metastable.

ii. Degree of Under cooling and Supersaturation.

iii. The loss in available heat drop due to irreversibility iv. Change in entropy

## Sample problems on Steam Turbine:

1. Steam at a velocity of 1000m/s enters a De-Laval turbine at an angle of 200 to a plane of the blade. The steam flow rate through the turbine is 1000 kg/hr and the mean blade velocity is 350m/s. If the inlet and outlet blade angles are equal, determine i. relative velocity of steam

at the inlet of the blades, ii. Blade angles, iii. Tangential force acting on the blades, iv. Power developed and v. Blade Efficiency. Take the blade velocity coefficient as 0.85.

2. The blade tips of a reaction turbine are inclined at 300 and 220 in the direction of motion. The guide vanes are of the same profile as that of the moving blades, but in the reversed direction. The condition of steam at a particular stage where the diameter of the drum is 1.2 m and height of the blade is 12 cm is 2 bar pressure and 0.9 dryness. If the turbine is running at 2200 rpm, determine i. the mass flow of steam ii. The power developed. Neglect the shock due to the flow of steam through the blades.

3. The data relevant to an impulse turbine are, velocity of steam from the nozzle is 450 m/s, nozzle angle 220,angle of moving blade exit 260,mean blade speed 175 m/s. Neglect friction. Calculate, i. angle of moving blade inlet, ii. Velocity of steam leaving, iii. Work developed per kg of steam, iv. Axial thrust and v. diagram or blade efficiency.

# **MULTIPLE CHOICE QUESTIONS:**

Questions	opt1	opt2	opt3	opt4	answer
A nozzle is said to be a convergent nozzle	when the cross- section of the nozzle increases continuously from entrance to exit	when the cross-section of the nozzle decreases continuously from entrance to exit	when the cross-section of the nozzle first decreases from entrance to throat and then increases from its throat to exit	none of the above	when the cross-section of the nozzle decreases continuously from entrance to exit
The flow through a nozzle is regarded as	constant volume flow	constant pressure flow	isothermal flow	isentropic flow	isentropic flow
The discharge of steam in a convergent- divergent nozzle after the throat (i.e. in the divergent portion of the nozzle)	remains constant	decreases	increases	Gradually vary	remains constant
In a nozzle, whole frictional loss is assumed to occur between	inlet and thoroat	inlet and outlet	throat and exit	all of these	throat and exit
The critical pressure ratio for initially wet steam is	0.546	0.577	0.582	0.601	0.582
The isentropic enthalpy drop in moving blade is two-third of the isentropic enthalpy drop in fixed blades of a turbine. The degree of reaction will be	0.4	0.56	0.67	1.67	0.4
In a De-Laval nozzle expanding superheated steam from 10 bar to 0.1	3.3 bar	5.46 bar	8.2 bar	9.9 bar	5.46 bar

bar, the pressure at the minimum cross- section (i. e. pressure at throat, $p_2$ ) will be					
The stage efficiency ( $\eta_s$ ) is given by (where $\eta_B$ = Blading efficiency, and $\eta_N$ = Nozzle efficiency)	$\eta_S = \eta_B \ge \eta_N$	$\eta_S=\eta_B/\eta_N$	$\eta_S=\eta_N/\eta_B$	$\eta_S = \eta_B + \eta_N$	$\eta_S = \eta_B \ x \ \eta_N$
The variation of steam pressure in the nozzle depends upon	velocity of steam	specific volume of steam	dryness fraction of steam	all of these	all of these
The steam enters the nozzle at a	high pressure and a low velocity	high pressure and a high velocity	low pressure and a low velocity	low pressure and a high velocity	high pressure and a low velocity
The difference of supersaturated temperature and saturation temperature at that pressure is called	degree of supersaturation	degree of superheat	degree of undercooling	none of these	degree of undercooling
The ratio of the useful heat drop to the isentropic heat drop is called	condenser efficiency	nozzle efficiency	boiler efficiency	vacuum efficiency	nozzle efficiency
The efficiency of steam turbines may be improved by	reheating of steam	regenerative feed heating	binary vapour plant	any one of these	any one of these
In a reaction turbine, when steam flows through the fixed blades,	pressure increases while velocity decreases	pressure decreases while velocity increases	pressure and velocity both decreases	pressure and velocity both increases	pressure decreases while velocity increases
The flow of steam is super-sonic	at the entrance to the nozzle	at the throat of the nozzle	in the convergent portion of the nozzle	in the divergent portion of the nozzle	in the divergent portion of the nozzle
De-Laval turbine is a	simple impulse turbine	simple reaction turbine	impulse- reaction turbine	none of these	simple impulse turbine

The impulse turbine rotor efficiency will have a maximum value of $0.5 \cos^2 \alpha$ , where $\alpha$ is the nozzle exit flow angle, if the	blades are equiangular	blade velocity coefficient is unity	blades are equiangular and frictionless	blade solidity is 0.65	blades are equiangular and frictionless
When the cross-section of a nozzle increases continuously from entrance to exit, it is called a	divergent nozzle	convergent nozzle	convergent- divergent nozzle	none of these	divergent nozzle
The critical pressure ratio for initially dry saturated steam is	0.546	0.577	0.582	0.601	0.577
The critical pressure ratio for gases is	0.528	0.546	0.577	0.582	0.528
The effect of supersaturation is that the	mass of the steam discharged increases	entropy and specific volume of the steam increases	exit velocity of steam reduces	all of these	all of these
The effect of friction on the flow of steam through a nozzle is to	decrease the mass flow rate and to increase the wetness of steam	increase the mass flow rate and to increase the exit temperature	decrease the mass flow rate and to decrease the wetness of steam	increase the exit temperature without any effect on mass flow rate	decrease the mass flow rate and to decrease the wetness of steam
The ratio of the isentropic heat drop to the heat supplied, is called	reheat factor	stage efficiency	internal efficiency	Rankine efficiency	Rankine efficiency
The purpose of governing in steam turbines is to	maintain the speed of the turbine	reduce the effective heat drop	reheat the steam and improve its quality	completely balance against end thrust	maintain the speed of the turbine
De-Laval turbines are mostly used	where low speeds are required	for small power purposes and	for large power purposes	for small power purposes and high speeds	for small power purposes and high speeds

		low speeds			
The reheat factor depends upon	initial pressure and superheat	exit pressure	turbine stage efficiency	all of these	all of these
In an impulse turbine	the steam is expanded in nozzles only and there is a pressure drop and heat drop	the steam is expanded both in fixed and moving blades continuously	the steam is expanded in moving blades only	the pressure and temperature of steam remains constant	the steam is expanded in nozzles only and there is a pressure drop and heat drop
A nozzle is said to be a divergent nozzle	when the cross- section of the nozzle increases continuously from entrance to exit	when the cross-section of the nozzle decreases continuously from entrance to exit	when the cross-section of the nozzle first decreases from entrance to throat and then increases from its throat to exit	none of the above	when the cross-section of the nozzle increases continuously from entrance to exit
The compounding of turbines is done in order to	reduce speed of rotor	improve efficiency	reduce exit losses	all of these	all of these
The process of maintaining the speed of the turbine constant for various load conditions, is known as	bleeding	reheating	governing	none of these	governing
The density of supersaturated steam is about that of the ordinary saturated vapour at the corresponding pressure.	same as	2 times	4 times	8 times	8 times
The ratio of the workdone on the blades	blading	nozzle	stage	mechanical	stage efficiency

per kg of steam to the total energy supplied per stage per kg of steam is called	efficiency	efficiency	efficiency	efficiency	
The diagram efficiency is the ratio of	workdone on the blades to the energy supplied to the blades	workdone on the blades per kg of steam to the total energy supplied per stage per kg of steam	energy supplied to the blades per kg of steam to the total energy supplied per stage per kg of steam	none of the above	workdone on the blades to the energy supplied to the blades
In order to reduce the rotor speed of an impulse turbine, the method employed is	velocity compounding	pressure compounding	pressure- velocity compounding	all of these	all of these
The nozzle efficiency is the ratio of	workdone on the blades to the energy supplied to the blades	workdone on the blades per kg of steam to the total energy supplied per stage per kg of steam	energy supplied to the blades per kg of steam to the total energy supplied per stage per kg of steam	none of the above	energy supplied to the blades per kg of steam to the total energy supplied per stage per kg of steam
In a reaction turbine	the steam is allowed to expand in the nozzle, where it gives a high velocity before	the expansion of steam takes place partly in the fixed blades and partly in the	the steam is expanded from a high pressure to a condenser pressure in	the pressure and temperature of steam remains constant	the expansion of steam takes place partly in the fixed blades and partly in the moving blades

	it enters the moving blades	moving blades	one or more nozzles		
A stage, in reaction turbine, is represented by	number of casing	number of entries of steam	number of exits of steam	each row of blades	each row of blades
When the nozzle operates with the maximum mass flow, the nozzle is said to be	choked	underdamping	overdamping	none of these	choked
In a velocity compounded impulse turbine, when steam flows through the second row of moving blades,	velocity increases	velocity decreases	velocity remains constant	pressure remains constant	velocity decreases
A steam nozzle converts	heat energy of steam into kinetic energy	kinetic energy into heat energy of steam	heat energy of steam into potential energy	potential energy into heat energy of steam	heat energy of steam into kinetic energy
The maximum discharge of steam through a convergent-divergent nozzle depends upon	area of nozzle at throat	initial pressure and volume of steam	final pressure ofsteam leaving the nozzle	both (a) and (b)	both (a) and (b)
The process of draining steam from the turbine, at certain points during its expansion and using this steam for heating the feed water in feed water heaters and then supplying it to the boiler is known as	regenerative heating	reheating of steam	bleeding	none of these	bleeding
In a 50% reaction turbine stage, tangential component of absolute velocity at rotor inlet is 537 m/s and the blade velocity is 454 m/s. The power output in kW of steam will be	260 kW	282 kW	296 kW	302 kW	282 kW

In an impulse turbine, steam expands	wholly in blades	wholly in nozzle	partly in the nozzle and partly in blades	none of these	wholly in nozzle
In a nozzle, the effect of supersaturation is to	decrease dryness fraction of steam	decrease specific volume of steam	increase the entropy	increase the heat drop	increase the entropy
Which of the following statement is correct?	The efficiency of steam turbines is greater than steam engines	A flywheel is a must for steam turbine.	The turbine blades do not change the direction of steam issuing from the nozzle	The pressure of steam, in reaction turbines, is increased in fixed blades as well as in moving blades	The efficiency of steam turbines is greater than steam engines
Which of the following statement is wrong?	The critical pressure gives the velocity of steam at the throat equal to the velocity of sound.	The flowin the convergent portion of the nozzle is sub- sonic.	The flow in the divergent portion of the nozzle is super-sonic.	To increase the velocity of steam above sonic velocity (super- sonic) by expanding steam below the critical pressure, the divergent portion for the nozzle is not necessary.	To increase the velocity of steam above sonic velocity (super-sonic) by expanding steam below the critical pressure, the divergent portion for the nozzle is not necessary.
In a reaction turbine when the degree of reaction is zero, then there is	no heat drop in moving blades	no heat drop in fixed blades	maximum heat drop in	maximum heat drop in fixed	no heat drop in moving blades
			moving	blades	
--	--	--	---	---	---
			blades		
In an ideal impulse turbine, the	absolute velocity at the inlet of moving blade is equal to that at the outlet	relative velocity at the inlet of the moving blade is equal to that at the outlet	axial velocity at inlet is equal to that at the outlet	whirl velocity at inlet is equalto that at the outlet	relative velocity at the inlet of the moving blade is equal to that at the outlet
In a reaction turbine, when steam flows through the moving blades,	pressure increases while velocity decreases	pressure decreases while velocity increases	pressure and velocity both decreases	pressure and velocity both increases	pressure and velocity both decreases
Stage efficiency is also known as	diagram efficiency	nozzle efficiency	gross efficiency	none of these	gross efficiency
In turbines, the fluid undergoes a continuous steady flow process and the speed of flow is	low	very low	high	very high	very high
In an impulse reaction turbine, the pressure drops gradually and continuously over	fixed blades	moving blades	both fixed and moving blades	none of these	both fixed and moving blades

# UNIT-IV AIR COMPRESSOR

## **Classification of compressors:**



The compressors are also classified based on other aspects like

- 1. Number of stages (single-stage, 2-stage and multi-stage),
- 2. Cooling method and medium (Air cooled, water cooled and oil-cooled),
- 3. Drive types (Engine driven, Motor driven, Turbine driven, Belt, chain, gear or direct coupling drives),
- 4. Lubrication method (Splash lubricated or forced lubrication or oil-free compressors).
- 5. Service Pressure (Low, Medium, High)

### **Positive Displacement compressors:**

# **Reciprocating Compressor:**

### Single-Acting Reciprocating compressor:

These are usually reciprocating compressors, which has piston working on air only in one direction. The other end of the piston is often free or open which does not perform any work. The air is compressed only on the top part of the piston. The bottom of the piston is open to crankcase and not utilized for the compression of air.



### **Double acting compressor:**

These compressors are having two sets of suction/intake and delivery valves on both sides of the piston. As the piston moves up and down, both sides of the piston is utilized in compressing the air. The intake and delivery valves operate corresponding to the stroke of the compressor. The compressed air delivery is comparatively continuous when compared to a single-acting air compressor. Thus both sides of the pistons are effectively used in compressing the air.



# **Diaphragm Compressors:**

In the diaphragm compressor, the piston pushes against a diaphragm, so the air does not come in contact with the reciprocating parts. This type compressor is preferred for food preparation, pharmaceutical, and chemical industries, because no effluent from the compressor enters the fluid.



### **Rotary compressors:**

### Lobe compressor:

The Lobe type air compressor is very simpler typewith no complicated moving parts. There are single or twin lobes attached to the drive shaft driven by the prime mover. The lobes are displaced by 90 degrees. Thus if one of the lobes is in horizontal position, the other

```
KARPAGAM ACADEMY OF HIGHER EDUCATION
```

### 15BEME501



at that particular instant will be in vertical position. Thus the air gets trapped in between these lobes and as they rotate they get compressed and delivered to the delivery line.

### Liquid ring compressor:

Liquid ring compressors require a liquid to create a seal. For medical applications, liquid ring compressors are always sealed with water but not oil. An impeller, which is offset so the impeller is not in the center of the pump housing, rotates and traps pockets of air in the space between the impeller fins and the compressor housing. The impeller is typically made of brass. As the impeller turns, there is a pocket of air that is trapped in the space between each of the fins. The trapped air is compressed between the impeller and the pump housing, sealed with the water ring. As the air is compressed, it's then pushed out of the pumps discharge. To avoid possible contaminants the compressor is always getting a supply of fresh sealing water. In a "once through" system, sealing water is drained and used only once, while in a "partial re-circulating" system, some (but never all) of the discharged water is re-circulated.



### Vane Type compressor:

The rotary slide vane-type, as illustrated in Figure, has longitudinal vanes, sliding radially in a slotted rotor mounted eccentrically in a cylinder. The centrifugal force carries the sliding vanes against the cylindrical case with the vanes forming a number of individual longitudinal cells in the eccentric annulus between the case and rotor. The suction port is located where the longitudinal cells are largest. The size of each cell is reduced by the eccentricity of the rotor as the vanes approach the discharge port, thus compressing the air.

This type of compressor, looks and functions like a vane type hydraulic pump. An eccentrically mounted rotor turns in a cylindrical housing having an inlet and outlet. Vanes slide back and forth in grooves in the rotor. Air pressure or spring force keeps the tip of these vanes in contact with the housing. Air is trapped in the compartments formed by the vanes and housing and is compressed as the rotor turns.



### Screw Type compressor:

The screw compressors are efficient in low air pressure requirements. Two screws rotate intermeshing with each other, thus trapping air between the screws and the compressor casing, forming pockets which progressively travel and gets squeezed and delivering it at a higher pressure which opens the delivery valve. The compressed air delivery is continuous and quiet in operation than a reciprocating compressor.

Rotary air compressors are positive displacement compressors. The most common rotary air compressor is the single stage helical or spiral lobe oil flooded screw air compressor. These compressors consist of two rotors within a casing where the rotors compress the air internally. There are no valves. These units are basically oil cooled (with air cooled or water cooled oil coolers) where the oil seals the internal clearances. Since the cooling takes place right inside the compressor, the working parts never experience extreme operating temperatures. The rotary compressor, therefore, is a continuous duty, air cooled or water cooled compressor package.





1	Inlet	6	Gas Path
2	Exhaust	7	Timing Gears
3	Water Jacket	8	Bearings
4	Screw	9	Shaft Seal
5	Oil	10	Oil Seal

# **Scroll Type Compressor:**

This type of compressor has a very unique design. There are two scrolls that look like loosely rolled up pieces of paper—one rolled inside the other. The orbiting scroll rotates inside of the stationary scroll. The air is forced into progressively smaller chambers towards the center. The compressed air is then discharged through the center of the fixed scroll. No inlet or exhaust valves are needed.





Non-Positive displacement compressors or Dynamic compressor:

# **Centrifugal Compressor:**

The centrifugal air compressor is a **dynamic** compressor which depends on transfer of energy from a **rotating impeller** to the air. Centrifugal compressors produce high-pressure discharge by converting angular momentum imparted by the rotating impeller (dynamic displacement). In order to do this efficiently, centrifugal compressors rotate at higher speeds than the other types of compressors. These types of compressors are also designed for higher capacity because flow through the compressor is continuous. Adjusting the inlet guide vanes is the most common method to control capacity of a centrifugal compressor. By closing the guide vanes, volumetric flows and capacity are reduced. The centrifugal air compressor is an oil free compressor by design. The oil lubricated running gear is separated from the air by shaft seals and atmospheric vents. The centrifugal air compressor is a dynamic compressor which depends on a rotating impeller to compress the air. In order to do this efficiently, centrifugal compressors must rotate at higher speeds than the other types of compressors. These types of compressors are designed for higher capacity because flow through the compressor is continuous and oil free by design.



Impeller

### **Axial Compressor:**

These are similar to centrifugal compressors except the direction of air flow is axial. The blades of the compressor are mounted onto the hub and in turn onto the shaft. As the shaft rotates at a high speed, the ambient air is sucked into the compressor and then gets compressed (high speed of rotation of the blades impart energy to the air) and directed axially for further usage. An axial flow compressor, in its very simple form is called as axial flow fan, which is commonly used for domestic purposes. The pressure built depends on the number of stages. These are commonly used as vent fans in enclosed spaces, blower ducts, etc. One can find its main application in the aerospace industry, where the gas turbines drive the axial flow air compressors.

### **Roots Blower Compressor:**

This type is generally called as blower. The discharge air pressure obtained from this type of machine is very low. The Discharge Pressure of 1 bar can be obtained in Single Stage and pressure of 2.2 bar is obtained from Stage. The discharge pressure achieved by two rotors which have separate parallel axis and rotate in opposite directions. This is the example of Positive Displacement Compressor in Rotary Type Air Compressor.



# **Multistage Compression:**

Multistage compression refers to the compression process completed in more than one stage i.e., a part of compression occurs in one cylinder and subsequently compressed air is sent to subsequent cylinders for further compression. In case it is desired to increase the compression ratio of compressor then multi-stage compression becomes inevitable. If we look at the expression for volumetric efficiency then it shows that the volumetric efficiency decreases with increase in pressure ratio. This aspect can also be explained using p-V representation shown in Figure.

A multi-stage compressor is one in which there are several cylinders of different diameters. The intake of air in the first stage gets compressed and then it is passed over a cooler to achieve a temperature very close to ambient air. This cooled air is passed to the intermediate stage where it is again getting compressed and heated. This air is again passed over a cooler to achieve a temperature as close to ambient as possible. Then this compressed air is passed to the final or the third stage of the air compressor where it is compressed to the required pressure and delivered to the air receiver after cooling sufficiently in an after-cooler.

### Advantages of Multi-stage compression:

- 1. The work done in compressing the air is reduced, thus power can be saved
- 2. Prevents mechanical problems as the air temperature is controlled
- 3. The suction and delivery valves remain in cleaner condition as the temperature and vaporization of lubricating oil is less
- 4. The machine is smaller and better balanced
- 5. Effects from moisture can be handled better, by draining at each stage
- 6. Compression approaches near isothermal
- 7. Compression ratio at each stage is lower when compared to a single-stage machine
- 8. Light moving parts usually made of aluminum, thus less cost and better maintenance

### Work done in a single stage reciprocating compressor without clearance volume:



Air enters compressor at pressure p1 and is compressed upto p2. Compression work requirement can be estimated from the area below the each compression process. Area on p-V diagram shows that work requirement shall be minimum with isothermal process 1-2". Work requirement is maximum with process 1-2 ie., adiabatic process. As a designer one shall be interested in a compressor having minimum compression work requirement. Therefore, ideally compression should occur isothermally for minimum work input. In practice it is not possible to have isothermal compression because constancy of temperature during compression can not be realized. Generally, compressors run at substantially high speed while isothermal compression requires compressor to run at very slow speed so that heat evolved during compression is dissipated out and temperature remains constant. Actually due to high speed running of compressor the compression process may be assumed to be near adiabatic or polytropic process following law of compression as Pvn=C with ofvarying

between 1.25 to 1.35 for air. Compression process following three processes is also shown on T-s diagram in Fig.16.4. it is thus obvious that actual compression process should be compared with isothermal compression process. A mathematical parameter called isothermal efficiency is defined for quantifying the degree of deviation of actual compression process from ideal compression process. Isothermal efficiency is defined by the ratio is isothermal work and actual indicated work in reciprocating compressor.

Practically, compression process is attempted to be closed to isothermal process by air/water cooling, spraying cold water during compression process. In case of multistage compression process the compression in different stages is accompanied by intercooling in between the stages. P2 V2. Mathematically, for the compression work following polytropic process, PVn=C. Assuming negligible clearance volume the cycle work done. Wc = Area on p-V diagram

The isothermal efficiency of a compressor should be close to 100% which means that actual compression should occur following a process close to isothermal process. For this the mechanism be derived to maintain constant temperature during compression process. Different arrangements which can be used are:

- Faster heat dissipation from inside of compressor to outside by use of fins over cylinder. Fins facilitate quick heat transfer from air being compressed to atmosphere so that temperature rise during compression can be minimized.
- Water jacket may be provided around compressor cylinder so that heat can be picked by cooling water circulating through water jacket. Cooling water circulation around compressor regulates rise in temperature to great extent.
- The water may also be injected at the end of compression process in order to cool the air being compressed. This water injection near the end of compression process requires special arrangement in compressor and also the air gets mixed with water and needs to be separated out before being used. Water injection also contaminates the lubricant film inner surface of cylinder and may initiate corrosion etc, The water injection is not popularly used.
- In case of multistage compression in different compressors operating serially, the air leaving one compressor may be cooled upto ambient state or somewhat high temperature before being injected into subsequent compressor. This cooling of fluid being compressed between two consecutive compressors is called intercooling and is frequently used in case of multistage compressors.

# Work done in a single stage reciprocating compressor with clearance volume:

Considering clearance volume: With clearance volume the cycle is represented on Figure. The work done for compression of air polytropically can be given by the are

aenclosed in cycle 1-2-3-4. Clearance volume in compressors varies from 1.5% to 35% depending upon type of compressor.





# **Sample Problems:**

1. A single stage single acting air compressor is used to compress air from 1.013 bar and  $25^{\circ}$  C to 7 bar according to law PV1.3 = C.The bore and stroke of a cylinder are

120mm and 150mm respectively. The compressor runs at 250 rpm .If clearance volume of the cylinder is 5% of stroke volume and the mechanical efficiency of the compressor is 85%, determine volumetric efficiency, power, and mass of air delivered per minute.

- A two stage singe acting air compressor compresses 2m3 air from 1 bar and 20° C to 15 bar. The air from the low pressure compressor is cooled to 25° C in the intercooler. Calculate the minimum power required to run the compressor if the compression follows PV1.25=C and the compressor runs at 400 rpm.
- 3. A single stage single acting air compressor is used to compress air from 1 bar and  $22^{\circ}$  C to 6 bar according to the law PV1.25 = C. The compressor runs at 125 rpm and the ratio of stroke length to bore of a cylinder is 1.5. If the power required by the compressor is 20 Kw, determine the size of the cylinder.

# MULTIPLE CHOICE QUESTIONS:

Questions	opt1	opt2	opt3	opt4	answer
Volumetric efficiency is	the ratio of stroke volume to clearance volume	the ratio of the air actually delivered to the amount of piston displacement	reciprocal of compression ratio	proportional to compression ratio	the ratio of the air actually delivered to the amount of piston displacement
To avoid moisture troubles, the branch connections from compressed air lines should be taken from	top side of main	bottom side of main	left side of main	right side of main	top side of main
After-cooler is used to	cool the air	decrease the delivery temperature for ease in handling	cause moisture and oil vapour to drop out	reduce volume	cause moisture and oil vapour to drop out
Which is false statement about multistage compression	Power consumption per unit of air delivered is low	Volumetric efficiency is high	It is best suited for compression ratios around 7:1	The moisture in air is condensed in the intercooler	Volumetric efficiency is high
Ratio of indicated h.p. to shaft h.p. in known as	compressor efficiency	isothermal efficiency	volumetric efficiency	mechanical efficiency	mechanical efficiency

1 m of air at atmospheric condition weighs approximately	0.5 kg	1.0 kg	1.3 kg	2.2 kg	1.3 kg
Aeroplanes employ following type of compressor	radial flow	centrifugal	combination of above	axial flow	axial flow
Clearance volume in actual reciprocating compressors is essential	to accommodate Valves in the cylinder head	to provide cushioning effect	to avoid mechanical bang of piston with cylinder head	to provide cushioning effect and also to avoid mechanical bang of piston with cylinder head.	to provide cushioning effect and also to avoid mechanical bang of piston with cylinder head.
In multistage compressor, the isothermal compression is achieved by	employing intercooler	by constantly cooling the cylinder	by running compressor at very slow speed	by insulating the cylinder	by running compressor at very slow speed
Which is false statement about air receivers	These are used to dampen pulsations	These act as reservoir to- take care of sudden demands	These increase compressor efficiency	These knock out some oil and moisture	These increase compressor efficiency
A compressor at high altitude will draw	more power	less power	same power	more/less power depending on other factors	less power

Volumetric efficiency of air compressors is of the order of	20-30%	40-50%	60-70%	70-90%	70-90%
The area of actual indicator diagram on an air compressor as compared to area of ideal indicator diagram is	less	more	same	more/less depending on compressor capacity	more
The- most efficient method of compressing air is to compress it	isothermally	adiabatically	isentropically	isochronically	isothermally
Ratio of indicated H.P. and brake H.P. is known as	mechanical efficiency	volumetric efficiency	isothermal efficiency	adiabatic efficiency	mechanical efficiency
An ideal air compressor cycle with clearance on p-v diagram can be represented by following processes	one adiabatic, two isobaric, and one constant volume	two adiabatic and two isobaric	two adiabatic, one isobaric and one constant volume	one adiabatic, one isobaric and two constant volume	two adiabatic and two isobaric
The overall isothermal eiffciency of compressor is defined as the ratio of	isothermal h.p. to the BHP of motor	isothermal h.p. to adiabatic h.p.	power to drive compressor to isothermal h.p.	work to compress air isothermally to work for actual compression	isothermal h.p. to the BHP of motor

Compression efficiency is compared against	ideal compression	adiabatic compression	isentropic compression	isothermal compression	isentropic compression
The work done per unit mass of air in compression will'be least when n is equal to	1	1.2	1.8	2.1	1
Adiabatic compression is one in which	no heat leaves or enters the compressor cylinder during compression	temperature rise follows a linear relationship	work done is maximum	temperature during compression remains constant	no heat leaves or enters the compressor cylinder during compression
Cylinder clearance in a compressor should be	as large as possible	as small as possible	about 50% of swept volume	about 100% of swept volume	as small as possible
The ratio of work done per cycle to the swept volume in case of compressor is called	compression index	compression ratio	compressor efficiency	mean effective pressure	mean effective pressure
Inter cooling in compressors	cools the delivered air	results in saving of power in compressing a given volume to given pressure	is the standard practice for big compressors	enables compression in two stages	results in saving of power in compressing a given volume to given pressure

An air compressor may be controlled by	throttle control (b) clearance control	blow-off control	any one of the above	none of the above	any one of the above
Rotary compressor is best suited for	large quantity of air at high pressure	small quantity of air at high pressure	small quantity of air at low pressure	large quantity of air at low pressure	small quantity of air at high pressure
Reciprocating air compressor is best suited for	large quantity of air at high pressure	small quantity of air at high pressure	small quantity of air at low pressure	large quantity of air at low pressure	large quantity of air at high pressure
Euler's equation is applicable for	centrifugal compressor	axial compressor	pumps	all of the above	all of the above
Volumetric efficiency of a compressor without clearance volume	increases with increase in compression ratio	decreases with increase in compression ratio	is not dependent upon compressin ratio	may increase/decrease depending on compressor capacity	is not dependent upon compressin ratio
The thrust on the rotor in a centrifugal compressor is produced by	radial component	axial component	tangential component	resultant component	axial component
The compressor performance at higher altitude compared to sea level will be	same	higher	lower	dependent on other factors	lower

To aviod moisture troubles, the compressed air main line should	rise gradually towards the point of use	drop gradually towards the point of use	be laid vertically	be laid exactly horizontally	drop gradually towards the point of use
Volumetric efficiency of a compressor with clearance volume	increases with increase in compression ratio	decreases with increase in compression ratio	in not dependent upon compression ratio	may increase/decrease depending on compressor capacity	decreases with increase in compression ratio
An ideal air compressor cycle without clearance on p-v diagram can be represented by following processes	one adiabatic, two isobaric, and one constant volume	two adiabatic and two isobaric	two adiabatic, one isobaric and one constant volume	one adiabatic, one isobaric and two constant volume	one adiabatic, two isobaric, and one constant volume
Isothermal compression efficiency, even when running at high speed, can be approached by using	multi-stage compression	cold water spray	both (a) and (b) above	fully insulating the cylinder	both (a) and (b) above
Isothermal compression efficiency can be attained by running the compressor	at very high speed	at very slow speed	at average speed	at zero speed	at very slow speed

The pressure and temperature conditions of air at the suction of compressor are	atmospheric	slightly more than atmospheric	slightly less than atmospheric	pressure sightly less than atmospheric and temperature slightly more than atmospheric	pressure sightly less than atmospheric and temperature slightly more than atmospheric
Isothermal compression though most efficient, but is not - practicable because	it requires very big cylinder	it does not increase pressure much	it is impossible in practice	compressor has to run at very slow speed to achieve it	compressor has to run at very slow speed to achieve it
The compressor efficiency is the	isothermal H.P/indicated H.R	isothermal H.P./shaft H.R	total output/air input	compression work/motor input	isothermal H.P/indicated H.R
Separators in compressor installations are located	after intercooler	after receiver	between after-cooler and air receiver	before suction	between after- cooler and air receiver
The capacity of compressor will be highest when its intake temperature is	lowest	highest	anything	atmospheric	atmospheric
Mining industry usually employs following motive power	A.C. electric motor	compressed air	petrol engine	diesel engine	compressed air
The clearance volume of the air compressor is kept minimum because	it allows maximum compression	it greatly affects volumetric	it results in minimum work	it permits isothermal compression	it greatly affects volumetric efficiency

	to be achieved	efficiency			
For a compressor, least work will be done if the compression is	is entropic	isothermal	poly tropic	somewhere in between is entropic and isothermal	isothermal
For slow-speed large capacity compressor, following type of valve will be best suited	poppet valve	mechanical valve of the corliss, sleeve, rotary or semirotary type	disc or feather type	any of the above	disc or feather type
More than one stage will be preferred for reciprocating compressor if the delivery pressure is more than	2 kg/cm2	6 kg/cm2	10 kg/cm2	14.7 kg/cm2	2 kg/cm2
During base load operation, the best method of controlling compressor is	start-stop motor	constant speed unloaded	relief valve	variable speed	start-stop motor
For supplying intermittent small quantity of air at high pressure, following compressor is best suited	centrifugal	reciprocating	axial	screw	reciprocating

The ratio of outlet whirl velocity to blade velocity in case of centrifugal compressor is called	slip factor	velocity factor	velocity coefficient	blade effectiveness	slip factor
The ratio of isentropic work to euler's work is known as	compressor efficiency	isentropic efficiency	Euler's efficiency	pressure coefficient	pressure coefficient
The indicated work per unit mass of air delivered is	directly proportional to clearance volume	greatly affected by clearance volume	not affected by clearance volume	inversely proportional to clearance volume	not affected by clearance volume
The capacity of a compressor is 5 m /mih. 5 m /min refers to	standard air	free air	compressed air	compressed air at delivery pressure	free air
Ratio of compression is the ratio of	gauge discharge pressure to the gauge intake pressure	absolute discharge pressure to the ab-solute intake pressure	pressures at discharge and suction cor- responding to same temperature	stroke volume and clearance volume	absolute discharge pressure to the ab- solute intake pressure

### UNIT-V REFRIGERATION AND AIR CONDITIONING

#### **Vapour Compression Refrigeration Cycle:**

*Process 1-2:* Isentropic compression of the refrigerant from state 1 to state 2. During this process work is done on the refrigerant by the surroundings. At the end of the process the refrigerant will be in superheated vapour state.



Process 2-3: Constant pressure condensation of the refrigerant in the condenser till it becomes a saturated liquid.

Process 3-4: Throttling expansion of the refrigerant from condenser pressure to the evaporator pressure.

Process 4-1: Constant pressure vapourisation of the refrigerant in the evaporator till it becomes a dry saturated vapour. During this process heat is absorbed by the refrigerant from the place to be refrigerated.

Applying steady flow steady state energy equation to the evaporator and neglecting the changes in kinetic and potential energies we have Refrigeration effect = QR = m (h1 - h4) Since process 3-4 is a throttling process, h4 = h3. Hence QR = m (h1 - h3) Similarly, by applying steady flow, steady state energy equation to compressor we get Compressor work input = Wc = m (h2 - h1)

$$COP = \frac{Q_R}{W_c} = \frac{(h_1 - h_4)}{(h_2 - h_1)}$$

Hence



### Sub cooling or Under cooling:



**Super Heating:** 



# Advantages of Vapour compression refrigeration system over air refrigeration system:

• Since the working cycle approaches closer to Carnot cycle, the C.O.P is quite high.

• Operational cost of vapour compression system is just above 1/4th of air refrigeration system.

• Since the heat removed consists of the latent heat of vapour, the amount of liquid circulated is less and as a result the size of the evaporator is smaller.

• Any desired temperature of the evaporator can be achieved just by adjusting the throttle valve.

# Disadvantages of Vapour compression refrigeration system over air refrigeration system

- Initial investment is high
- Prevention of leakage of refrigerant is a major problem

**Refrigerant:** A refrigerant is a fluid in a refrigerating system that by its evapourating takes the heat of the cooling coils and gives up heat by condensing the condenser.

**Identifying refrigerants by numbers:**The present practice in the refrigeration industry is to identify refrigerants by numbers. The identification system of numbering has been standardized by the American society of heating, refrigerating and air conditioning engineers (ASHRAE), some refrigerants in common use are

Refrigeration	Name and Chemical
	Formula
R-11	Trichloromonofluorometh
	ane,CCl3F
R-12	Dichlorodifluoromethane
	CCl2F2
R-22	Monochlorodifluorometha
	ne ,CHClF2
R-717	Ammonia ,NH3
R114(R4	Azeotropic mixture of
0)	73.8%
R-500	(R-22) and 26.2% R-
R502	152a Azeotropic mixture
	of 48.8% (R-22) and
	51.2% R-115
<b>R-764</b>	Sulphur Dioxide SO2

# **Properties of Refrigerants**

• Toxicity: It obviously desirable that the refrigerant have little effect on people

• **Inflammability:** Although refrigerants are entirely sealed from the atmosphere, leaks are bound to develop. If the refrigerant is inflammable and the system is located where ignition of the refrigerant may occur, a great hazard is involved.

• **Boiling Point**: An ideal refrigerant must have low boiling temperature at atmospheric pressure

• **Freezing Point :**An ideal refrigerant must have a very low freezing point because the refrigerant should not freeze at low evaporator temperatures.

•evaporator**and condenser pressure:**In order to avoid the leakage of the atmosphere air and also to enable the detection of the leakage of the refrigerant, both the evaporator and condenser pressure should be slightly above the atmosphere pressure.

• Chemical Stability : An ideal refrigerant must not decompose under operating conditions..

• Latent heat of Evapouration: The Latent heat of Evapouration must be very high so that a minimum amount of refrigerant will accomplish the desired result; in other words, it increases the refrigeration effect

• **Specific Volume:**The Specific Volume of the refrigerant must be low. The lower specific volume of the refrigerant at the compressor reduces the size of the compressor.

• **Specific heat of liquid vapour**: A good refrigerant must have low specific heat when it is in liquid state and high specific heat when it is vapourized

• **Viscosity** :The viscosity of the refrigerant t both the liquid and vapour state must be very low as improved the heat transfer and reduces the pumping pressure.

• **Corrosiveness:**A good refrigerant should be non-corrosive to prevent the corrosion of the metallic parts of the refrigerator.

• **Odour**: A good refrigerant must be odourless, otherwise some foodstuff such as meat, butter, etc. loses their taste

• **Oil solvent properties**: A good refrigerant must be not react with the lubricating oil used in the refrigerator for lubricating the parts of the compressor.

**Ton of refrigeration:** Amount of heat required to Melt a Ton of Ice in a 24/h Period One ton of refrigeration is the heat required to melt 1 ton of ice in 24 hrs. That is, a refrigeration machine rated at 1 ton cools as much in 24 hrs. as 1 ton of ice would by melting in the same period. The heat required is the product of the latent heat of fusion and the mass in kg.

Q = mH, 1 ton = 907 kg latent heat of fusion: H = 340 kJ/kg Q = 907\*340 = 308380 kJ The power required is then: P = E/t = Q/t = 308380 kJ/24 hr = 308380/(24\*3600) = 3.57 kw

```
KARPAGAM ACADEMY OF HIGHER EDUCATION
```

Note: 1 watt = 1 J/s so that 1 kw = 1 kJ/s



# Ammonia Water vapour absorption refrigeration system:

- 1) **evaporator** : It is in the evaporator where the refrigerant pure ammonia (NH3) in liquid state produces the cooling effect. It absorbs the heat from the substance to be cooled and gets evapourated. From here, the ammonia passes to the absorber in the gaseous state.
- 2) 2) Absorber: In the absorber the weak solution of ammonia-water is already present. The water, used as the absorbent in the solution, is unsaturated and it has the capacity to absorb more ammonia gas. As the ammonia from evaporator enters the absorber, it is readily absorbed by water and the strong solution of ammonia-water is formed. During the process of absorption heat is liberated which can reduce the ammonia absorption capacity of water; hence the absorber is cooled by the cooling water. Due to absorption of ammonia, strong solution of ammonia-water is formed in the absorber.
- **3) Pump**: The strong solution of ammonia and water is pumped by the pump at high pressure to the generator.

- **4) Generator**: The strong solution of ammonia refrigerant and water absorbent are heated by the external source of heat such as steam or hot water. It can also be heated by other sources like natural gas, electric heater, waste exhaust heat etc. Due to heating the refrigerant ammonia gets vapourized and it leaves the generator. However, since water has strong affinity for ammonia and its vapourization point is quite low some water particles also get carried away with ammonia refrigerant, so it is important to pass this refrigerant through analyzer.
- 5) Analyzer: One of the major disadvantages of the ammonia-water vapour absorption refrigeration system is that the water in the solution has quite low vapourizing temperature, hence when ammonia refrigerant gets vapourized in the generator some water also gets vapourized. Thus the ammonia refrigerant leaving the generator carries appreciable amount of water vapour. If this water vapour is allowed to be carried to the evaporator, the capacity of the refrigeration system would reduce. The water vapour from ammonia refrigerant is removed by analyzer and the rectifier. The analyzer is a sort of the distillation column that is located at the top of the generator. The analyzer consists of number of plates positioned horizontally. When the ammonia refrigerant along with the water vapour particles enters the analyzer, the solution is cooled. Since water has higher saturation temperature, water vapour gets condensed into the water particles that drip down into the generator. The ammonia refrigerant in the gaseous state continues to rise up and it moves to the rectifier.
- 6) **Rectifier or the reflex condenser**: The rectifier is a sort of the heat exchanger cooled by the water, which is also used for cooling the condenser. Due to cooling the remaining water vapour mixed with the ammonia refrigerant also gets condensed along with some particles of ammonia. This weak solution of water and ammonia drains down to the analyzer and then to the generator.
- 7) Condenser and expansion valve: The pure ammonia refrigerant in the vapour state and at high pressure then enters the condenser where it is cooled by water. The refrigerant ammonia gets converted into the liquid state and it then passes through the expansion valve where its temperature and pressure falls down suddenly. Ammonia refrigerant finally enters the evaporator, where it produces the cooling effect. This cycle keeps on repeating continuously. Meanwhile, when ammonia gets vapourized in the generator, weak solution of ammonia and water is left in it. This solution is expanded in the expansion valve and passed back to the absorber and its cycle repeats.

### Lithium Bromide-Water vapours absorption refrigeration system:

1) This refrigeration system is used for large tonnage capacity. In this system, lithiumbromide is acting as the absorbent and water is acting as refrigerant. Thus in the absorber the lithium bromide absorbent absorbs the water refrigerant and solution of water and lithium bromide is formed. This solution is pumped by the pump to the generator where the solution is heated. The water refrigerant gets vapourized and moves to the condenser where it is heated while lithium bromide flows back to the absorber where it further absorbs water coming from the evaporator. The waterlithium bromide vapour absorption system is used in a number of air conditioning applications.



### **Special Features of Water-Lithium Bromide Solution**

- Here are some special features of the water and lithium bromide in absorption refrigeration system: 1) As such lithium bromide has great affinity for water vapour, however, when the water-lithium bromide solution is formed, they are not completely soluble with each other under all the operating conditions of the absorption refrigeration system. Hence, when the water-lithium bromide absorption refrigeration system is being designed, the designer must take care that such conditions would not be created where the crystallization and precipitation of lithium bromide would occur.
- 2) The water used as the refrigerant in the absorption refrigeration system means the operating pressures in the condenser and the evaporator would be very low. Even the difference of pressure between the condenser and the evaporator are very low, and this can be achieved even without installing the expansion valve in the system, since the drop in pressure occurs due to friction in the refrigeration piping and also in the spray nozzles. 3) The capacity of any absorption refrigeration system depends on the ability of the absorbent to absorb the refrigerant, which in turn depends on the concentration of the absorbent. To increase the capacity of the system, the concentration of absorbent should be increased, which would enable absorption of more refrigerant. Some of the most common methods used to change the concentration of the absorbent are: controlling the flow of the steam or hot water to the generator, controlling the flow of water used for condensing in the condenser, and re-concentrating the absorbent leaving the generator and entering the absorber.

### Parts of the Water-Lithium Bromide Absorption Refrigeration and their Working :

1) Let us see various parts of the water-lithium bromide absorption refrigeration and their working (please refer the figure above):

1) **Evaporator:** Water as the refrigerant enters the evaporator at very low pressure and temperature. Since very low pressure is maintained inside the evaporator the water exists in the partial liquid state and partial vapour state. This water refrigerant absorbs the heat from the substance to be chilled and gets fully evapourated. It then enters the absorber.

**2) Absorber**: In the absorber concentrated solution of lithium bromide is already available. Since water is highly soluble in lithium bromide, solution of water-lithium bromide is formed. This solution is pumped by the pump to the generator.

**3) Generator**: The heat is supplied to the refrigerant water and absorbent lithium bromide solution in the generator from the steam or hot water. Due to heating water gets vapourized and it moves to the condenser, where it gets cooled. As water refrigerant moves further in the refrigeration piping and though nozzles, it pressure reduces and so also the temperature. This water refrigerant then enters the evaporator where it produces the cooling effect. This cycle is repeated continuously. Lithium bromide on the other hand, leaves the generator and renters the absorber for absorbing water refrigerant. As seen in the image above, the condenser water is used to cool the water refrigerant in the condenser and the water-Li Br solution in the absorber. Steam is used for heating water-Li Br solution in the generator. To change the capacity of this water-Li Br absorption refrigeration system the concentration of Li Br can be changed.

Compression systems	Absorption systems
Work operated	Heat operated
High COP	Low COP (currently maximum $\approx 1.4$ )
Performance (COP and capacity) very	Performance not very sensitive to
sensitive to evaporator temperatures	evaporator temperatures
System COP reduces considerably at	COP does not reduce significantly with
part loads	load
Liquid at the exit of evaporator may	Presence of liquid at evaporator exit is
damage compressor	not a serious problem
Performance is sensitive to evaporator	Evaporator superheat is not very
superheat	important
Many moving parts	Very few moving parts
Regular maintenance required	Very low maintenance required
Higher noise and vibration	Less noise and vibration
Small systems are compact and large	Small systems are bulky and large
systems are bulky	systems are compact

### 2) Comparison between vapour compression and vapour absorption systems:

**Psychrometry:** Psychrometry is the science of studying thermodynamic properties of moist air and the use of these to analyze conditions and processes involving moist air. **Terminologies used in Psychrometry:** 

# **Dry-Bulb Temperature -** *Tdb*

Dry-Bulb Temperature, usually referred to as the air temperature, is the air property that is most commonly used. People referring to air temperature normally referring to Dry Bulb Temperature. Dry-Bulb Temperature - Tdb- can be measured by using a normal thermometer. With Dry-Bulb Temperature the sensible heat content in the air can be determined along the bottom axis of the psychrometric chart. The vertical lines extending upward from this axis are constant-temperature lines.

# Wet-Bulb Temperature - *Twb*

- 1) Wet-Bulb Temperature is associated with the moisture content of the air. Wet Bulb Temperature can be measured with a thermometer that has the bulb covered with a water-moistened bandage with air flowing over the thermometer.
- 2) Wet-Bulb Temperatures are always lower than dry bulb temperatures with less than 100% relative humidity in the air. The Wet-Bulb Temperature and the Dry-Bulb Temperature will be identical with 100% relative humidity in the air (the air is at the saturation line). On the chart, the Wet-Bulb Temperature lines slopes a little upward to the left, and the temperature is read at the saturation line.

# **Relative Humidity -***RH*

Relative Humidity is the ratio of water vapour pressure - pw, to the water vapour pressure of saturated air at the same temperature - pws, expressed as a percentage. Relative humidity is a relative measure. The moisture-holding capacity of air increases with air temperature. In practice the relative humidity will indicate the moisture level of the air compared to the maximum moisture-holding capacity of air at saturation.

### **Dew Point Temperature -** *Tdp*

Dew Point is the temperature at which water vapour starts to condense in the air - the temperature at which air becomes completely saturated. Above this temperature the moisture stays in the air. The Dew Point Temperature can be read in the psychrometric charts by following the horizontal line from the state-point to the saturation line. The Dew Point Temperature is represented along the 100% relative humidity line.

# Specific Volume of Humid Air - v

1) Specific Volume represents the space occupied by a unit weight of dry air (ft3/lb, m3/kg). Specific volume is indicated along the bottom axis of the psychrometric chart with the constant-volume lines slanting upward to the left.

# Moisture Content and Humidity Ratio - x

**Moisture Content** and **Humidity Ratio** is the amount of water vapour by weight in dry air. The moisture content of air is expressed as the weight of water vapour per unit weight of dry air (*lbH2O/lbair, kgH2O/kgair*). Humidity ratio is indicated along the right-hand axis in psychrometric charts.

### Enthalpy - h

- 1) Enthalpy is the measure of the total thermal energy in air.
- 2) Energy content is expressed as energy per unit weight of air (*Btu/lbair, J/kgair*). Enthalpy in the psychrometric chart can read from where the appropriate wet-bulb line crosses the diagonal scale above the saturation curve. Air with the same amount of energy may either be drier hotter air (higher sensible heat) or cooler moister air (higher latent heat).

# 3) Psychrometric Chart:



**Psychrometric Processes: Sensible Cooling:** The sensible cooling of air is the process in which only the sensible heat of the air is removed so as to reduce its temperature, and there is no change in the moisture content (kg/kg of dry air) of the air. During sensible cooling process the dry bulb (DB) temperature and wet bulb (WB) temperature of the air reduces, while the latent heat of the air, and the dew point (DP) temperature of the air remains constant. There is overall reduction in the enthalpy of the air. The sensible cooling process is represented by a straight horizontal line on the psychrometric chart. The line starts from the initial DB temperature of the air and ends at the final DB temperature of the air and ends at the final DB temperature (see the figure below). The sensible cooling line is also the constant DP temperature line since the moisture content of the air remains constant. The initial and final points on the psychrometric chart give all the properties of the air.



**Sensible Heating:** Sensible heating process is opposite to sensible cooling process. In sensible heating process the temperature of air is increased without changing its moisture content. During this process the sensible heat, DB and WB temperature of the air increases while latent of air, and the DP point temperature of the air remains constant. Like the sensible cooling, the sensible heating process is also represented by a straight horizontal line on the psychrometric chart. The line starts from the initial DB temperature of air and ends at the final temperature extending towards the right (see the figure). The sensible heating line is also the constant DP temperature line.



**Cooling and Humidification:** During the cooling and humidification process the dry bulb of the air reduces, it's wet bulb and the dew point temperature increases, while its moisture content and thus the relative humidity also increases. Also, the sensible heat of
the air reduces, while the latent heat of the air increases resulting in the overall increase in the enthalpy of the air. Cooling and humidification process is represented by an angular line on the psychrometric chart starting from the given value of the dry bulb temperature and the relative humidity and extending upwards toward left.



**Heating and Humidification:** During heating and humidification process the dry bulb, wet bulb, and dew point temperature of the air increases along with its relative humidity. The heating and humidification process is represented on the psychrometric chart by an angular line that starts from the given value of the dry bulb temperature and extends upwards towards right (see the figure below).



**Cooling and Dehumidification:** During the cooling and dehumidification process the dry bulb, wet bulb and the dew point temperature of air reduces. Similarly, the sensible heat

and the latent heat of the air also reduce leading to overall reduction in the enthalpy of the air. The cooling and dehumidification process is represented by a straight angular line on the psychrometric chart. The line starts from the given value of the DB temperature and extends downwards towards left.



**Heating and Dehumidification:** During the heating and dehumidification process dry bulb temperature of the air increases while its dew point and wet bulb temperature reduces. On the psychrometric chart, this process is represented by a straight angular line starting from the given DB temperature conditions and extending downwards towards right to the final DB temperature conditions.



### **Adiabatic Mixing:**



Saturated air leaving the cooling section of an air conditioning system at T1°C at a rate of V1 (m3/min) is mixed adiabatically with outside air at T2°C and RH2 percent relative humidity at a rate of V2 (m3/min). Assuming that the mixing process occurs at a pressure of P(atm), determine the specific humidity, the relative humidity, the dry-bulb temperature, and the volume flow rate of the mixture.

#### Adiabatic Humidification:



Adiabatic humidification occurs when water vapour is added to the atmosphere. Specific humidity will increase, along the wet bulb temperature line. Reduction in dry bulb temperature will happen as, the evaporated water will absorb heat. A humidifier will perform this function.

**Cooling Load Calculation: Load due to heat transfer:** 

### **1.Cooling Load Temperature Difference :**

The space sensible cooling load Qrs is calculated as:

$$Q_{rs} = A \cdot U \cdot CLTD$$

where A = area of external wall or roof

U = overall heat transfer coefficient of the external wall or roof. CLTD values are found from tables.

#### **2.Cooling Load Factor:**

The cooling load factor is defined as:

$$CLF = \frac{\text{sensible cooling load}}{\text{sensible heat gain}} = \frac{Q_{rs}}{Q_{es}}$$

#### 3.Conduction Heat Gain through Roofs (Qrs) and External Walls (Qws) :

The space cooling load due to the conduction heat gain through roofs or external walls is calculated as:

$$Q_{rs}$$
 (or  $Q_{rs}$ ) =  $A \cdot U \cdot CLTD$ 

where A = area for external walls or roofs

U = overall heat transfer coefficient for external walls or roof

#### **4.Electric Lighting :**

Space cooling load due to the heat gain from electric lights is often the major component for commercial buildings having a larger ratio of interior zone. Electric lights contribute to sensible load only. Sensible heat released from electric lights is in two forms:

- (i) Convective heat from the lamp, tube and fixtures.
- (ii) Radiation absorbed by walls, floors, and furniture and convicted by the ambient air after a time lag. The sensible heat released (Qles) from electric lights is calculated as:

$$Q_{les} = Input \cdot F_{use} \cdot F_{al}$$

where Input = total light wattage obtained from the ratings of all fixtures installed

Fuse = use factor defined as the ratio of wattage in use possibly at design condition to the installation condition

Fal = special allowance factor for fluorescent fixtures accounting for ballast loss, varying from 1.18 to 1.30.

The corresponding sensible space cooling load (Qls) due to heat released from electrical light is:

$$\mathbf{Q}_{\mathtt{ls}} = \mathtt{Input} \cdot \mathbf{F}_{\mathtt{use}} \cdot \mathbf{F}_{\mathtt{al}} \cdot \mathtt{CLF}$$

CLF is a function of

- (i) number of hours that electric lights are switched on (for 24 hours continuous lighting, CLF = 1), and
- (ii) Types of building construction and furnishings. Therefore, CLF depends on the magnitude of surface and the space air flow rates.

#### Load due to heat generation:

#### **Classification of heat loads:**

**Sensible Heat: Sensible** heat is the heat absorbed or given off by a substance that is NOT in the process of changing its physical state. Sensible heat can be sensed, or measured, with a thermometer, and the addition or removal of sensible heat will always cause a change in the temperature of the substance.

**Latent Heat: Latent** heat is the heat absorbed or given off by a substance while it is changing its physical state. The heat absorbed or given off does NOT because a temperature changes in the substance- the heat is latent or hidden. In other words, sensible heat is the heat that affects the temperature of things; latent heat is the heat that affects the physical state of things.

#### **Concepts of GSHF, RSHF, ESHF:**

**Gross Sensible Heat Factor:**It is defined as the ratio of gross sensible heat to the gross total heat.

#### GSHF= GSH/GTH

**Effective Sensible Heat Factor:** It is the ratio of effective room sensible heat to the effective room total heat.

#### ESHF= ERSH/ERTH.

Room Sensible Heat Factor: It is the ratio of room sensible heat to the room total heat.

#### **Types of Air- Conditioning System:**

**Central Systems:** The central air conditioning system is used for cooling big buildings, houses, offices, entire hotels, gyms, movie theatres, factories etc. If the whole building is to be air conditioned, HVAC engineers find that putting individual units in each of the rooms is

very expensive initially as well in the long run. The central air conditioning system is comprised of a huge compressor that has the capacity to produce hundreds of tons of air conditioning. Cooling big halls, malls, huge spaces, galleries etc is usually only feasible with central conditioning units.







A zoned air conditioning system using a room air terminal which has the same horizontal dimensions as a floor tile of a raised tile floor such that the terminal may replace one tile in such a floor. The terminal includes a cool air inlet below the floor for drawing in cooling air circulated in the under floor space and a return air inlet in the top surface of the terminal. The cool air and return air is mixed in a mixing chamber and drawn from the mixing chamber by a fan and returned to the room through an outlet vent. The ratio of cool air to return air mixed in the mixing chamber is controlled by a modulating damper which is controlled in response to the terminal in accordance with an adjustable set point. A heater is also provided in the terminal for those occasions where the return air is cooler than the set point.

#### **Unitary Systems:**

A unitary air conditioning system comprises an outdoor unit including a compressor for compressing a refrigerant, an outdoor heat exchanger for heat exchange of the refrigerant and an expander connected to the outdoor heat exchanger, for expanding the refrigerant; a duct installed inside a zone of a building; a central blower unit having a heat exchanger connected to the outdoor unit through a first refrigerant pipe and a blower for supplying the air heatexchanged by the heat exchanger to the duct; and an individual blower unit including a heat exchanger connected to the outdoor unit through a second refrigerant pipe and a fan for sending the air heat-exchanged by the heat exchanger and disposed in a zone in the building, for individually cooling or heating the zone. Accordingly, cooling or heating operation is performed on each zone of the building, and simultaneously, additional individual heating or cooling operation can be performed on a specific space, so that a cost can be reduced, and cooling or heating in the building can be efficiently performed.



#### Window Air-conditioning System:

It is the most commonly used air conditioner for single rooms. In this air conditioner all the components, namely the compressor, condenser, expansion valve or coil, evaporator and cooling coil are enclosed in a single box. This unit is fitted in a slot made in the wall of the room, or often a window sill.

Windows air conditioners are one of the most widely used types of air conditioners because they are the simplest form of the air conditioning systems. Window air conditioner comprises of the rigid base on which all the parts of the window air conditioner are assembled. The base is assembled inside the casing which is fitted into the wall or the window of the room in which the air conditioner is fitted. The whole assembly of the window air conditioner can be divided into two compartments: the room side, which is also the cooling side and the outdoor side from where the heat absorbed by the room air is liberated to the atmosphere. The room side and outdoor side are separated from each other by an insulated partition enclosed inside the window air conditioner assembly (refer fig 1 below).

In the front of the window air conditioner on the room side there is beautifully decorated front panel on which the supply and return air grills are fitted (the whole front panel itself is commonly called as front grill). The louvers fitted in the supply air grills are adjustable so as to supply the air in desired direction. There is also one opening in the grill that allows access to the control panel or operating panel in front of the window air conditioner.



- 1) **Blower:** This is the small blower that is fitted behind the evaporator or cooling coil inside the assembly of the window air conditioner system. The blower sucks the air from the room which first passes over the air filter and gets filtered. The air then passes over the cooling coil and gets chilled. The blower then blows this filtered and chilled air, which passes through the supply air compartment inside the window air conditioner assembly. This air is then delivered into the room from the supply air grill of the front panel.
- 2) **Propeller fan or the condenser fan:** The condenser fan is the forced draft type of propeller fan that sucks the atmospheric air and blows it over the condenser. The hot refrigerant inside the condenser gives up the heat to the atmospheric air and its temperature reduces.
- **3) Fan motor:** The motor inside the window air conditioner assembly is located between the condenser and the evaporator coil. It has double shaft on one side of which the blower is fitted and on the other side the condenser fan is fitted. This makes the whole assembly of the blower, the condenser fan and the motor highly compact.

#### **Split Air- Conditioning System:**

The split air conditioner comprises of two parts: the outdoor unit and the indoor unit. The outdoor unit, fitted outside the room, houses components like the compressor, condenser and expansion valve. The indoor unit comprises the evaporator or cooling coil and the cooling fan. For this unit you don't have to make any slot in the wall of the room. Further, the present day split units have aesthetic looks and add to the beauty of the room. The split air conditioner can be used to cool one or two rooms.



1) Evaporator Coil or the Cooling Coil: The cooling coil is a copper coil made of number turns of the copper tubing with one or more rows depending on the capacity of the air conditioning system. The cooling coil is covered with the aluminium fins so that the maximum amount of heat can be transferred from the coil to the air inside the room. The refrigerant from the tubing at very low temperature and very low pressure enters the cooling coil. The blower absorbs the hot room air or the atmospheric air and in doing so the air passes over the cooling coil which leads to the cooling of the air. This air is then blown to the room where the cooling effect has to be produced. The air, after producing the cooling effect is again sucked by the blower and the process of cooling the room continues. After absorbing the heat from the room air, the temperature of the refrigerant inside the cooling coil becomes high and it flows back through the return copper tubing to the compressor inside the outdoor unit and that supplying the refrigerant from the outdoor unit are both covered with the insulation tape.

2) Air Filter: The air filter is very important part of the indoor unit. It removes all the dirt particles from the room air and helps supplying clean air to the room. The air filter in the wall mounted type of the indoor unit is placed just before the cooling coil. When the blower sucks the hot room air, it is first passed through the air filter and then though the cooling coil. Thus the clean air at low temperature is supplied into the room by the blower.

**3)** Cooling Fan or Blower: Inside the indoor unit there is also a long blower that sucks the room air or the atmospheric air. It is an induced type of blower and while is sucks the room air it is passed over the cooling coil and the filter due to which the temperature of the air reduces and all the dirt from it is removed. The blower sucks the hot and unclean air from the room and supplies cool and clean air back. The shaft of the blower rotates inside the bushes and it is connected to a small multiple speed motor, thus the speed of the blower can be

changed. When the fan speed is changed with the remote it is the speed of the blower that changes.

**4) Drain Pipe:** Due to the low temperature refrigerant inside the cooling coil, its temperature is very low, usually much below the dew point temperature of the room air. When the room air is passed over the cooling due the suction force of the blower, the temperature of the air becomes very low and reaches levels below its dew point temperature. Due to this the water vapour present in the air gets condensed and dew or water drops are formed on the surface of the cooling coil. These water drops fall off the cooling coil and are collected in a small space inside the indoor unit. To remove the water from this space the drain pipe is connected from this space extending to the some external place outside the room where water can be disposed off. Thus the drain pipe helps removing dew water collected inside the indoor unit. To remove the water collected in the space easily and drained out. If this angle is in opposite direction, all the water will get drained inside the room. Also, if the tilt angle is too high, the indoor unit will shabby inside the room.

#### 5) Louvers or Fins:

The cool air supplied by the blower is passed into the room through louvers. The louvers help changing the angle or direction in which the air needs to be supplied into the room as per the requirements. With louvers one easily changes the direction in which the maximum amount of the cooled air has to be passed.

There are two types of louvers: horizontal and vertical. The horizontal louvers are connected to a small motor and their position can set by the remote control. Once can set a fixed position for the horizontal louvers so that chilled air is passed in a particular direction only or one can keep it in rotation mode so that the fresh air is supplied throughout the room. The vertical louvers are operated manually and one can easily change their position as per the requirements. The horizontal louvers control flow of air in upper and downward directions of the room, while vertical louvers control movement of air in left and right directions.

#### **Sample Problems:**

1. A sling psychrometer in a lab test recorded the following readings DBT=35°C, WBT=25°C Calculate the following Specific humidity Relative humidity Vapour density in air Dew point temperature. Enthalpy of mixing per kg of air take atmospheric pressure=1.0132 bar.

2. A food storage locker requires a refrigeration system of 12 tons capacity at an evaporator temperature of -8°C and a condenser temperature of 30°C. The refrigerant freon-12 is sub cooled to 25°C before entering the expansion valve and the vapour is superheated to -2°C before entering the compressor. The compression of the refrigerant is reversible adiabatic. A double action compressor with stroke equal to 1.5 times the bore is to be used operating at 900 rpm, Determine,

- COP
- Theoretical piston displacement/min
- Mass of refrigerant to be circulated/min
- Theoretical bore and stroke of the compressor.

Take liquid specific heat of refrigerant as 1.23 kJ/kg K and the specific heat of vapour refrigerant is 0.732 kJ/kg K.

3. A vapour compression refrigerator working with Freon-12 has its temperature range -10°C and 30°C. The Vapour enters the compressor dry and under cooled by 5°C in the condenser. For a capacity of 15 TOR, find: (a)C.O.P (b) mass of freon (c) Power required. Cp for vapour = 0.56kJ/kgKCp for liquid = 1.003kJ/kgK Refer tables for properties of Freon 12.

# MULTIPLE CHOICE QUESTIONS

Questions	opt1	opt2	opt3	opt4	answer
Air refrigeration operates on	Carnot cycle	Reversed Carnot cycle	Brayton cycle.	Rankine cycle	Brayton cycle.
Formation of frost on evaporator in refrigerator	results in loss of heat due to poor heat transfer	increases heat transfer rate	can be avoided by proper design	decreases compressor power.	results in loss of heat due to poor heat transfer
Refrigeration in aeroplanes usually employs the following refrigerant	C02	Freon-11	Freon-22	Air	Air
Highest temperature encountered in refrigeration cycle should be	near critical temperature of refrigerant	above critical temperature	much below critical temperature	could be anywhere	much below critical temperature
Accumulators should have adequate volume to store refrigerant charge at least	10%	25%	50%	100%	50%
Air refrigeration cycle is used in	domestic refrigerators	commercial refrigerators	air conditioning	gas liquefaction	gas liquefaction

## 15BEME501

Presence of moisture in a refrigerant affects the working of	compressor	condenser	evaparator	expansion valve.	expansion valve.
In a vapour compression cycle, the refrigerant immediately after expansion valve is	liquid	saturated liquid	wet vapour	dryvapour.	wet vapour
The bank of tubes at the back of domestic refrigerator are	condenser tubes	evaporator tubes	capillary tubes	throttling device	condenser tubes
The value of COP in vapour compression cycle is usually	always less than unity	always more than unity	equal to unity	any one of the above	always more than unity
Absorption system normally uses the following refrigerant	Freon-11	Freon-22	S02	ammonia.	ammonia.

One of the purposes of sub-cooling the liquid refrigerant is to	reduce compressor overheating	reduce compressor discharge tempera- ture	increase cooling effect	ensure that only liquid and not the vapour enters the expansion (throttling) valve	ensure that only liquid and not the vapour enters the expansion (throttling) valve
The domestic refrigerator uses following type of compressor	centrifugal	axial	miniature sealed unit	piston type reciprocating	piston type reciprocating
In a refrigeration system, heat absorbed in comparison to heat rejected is	more	less	less for small capacity and more for high capacity	more for small capacity and less for high capacity	less

For better COP of refrigerator, the pressure range corresponding to temperature in evaporator and condenser must be	small	high	equal	anything	small
The COP of a domestic refrigerator	is less than 1	is more than 1	is equal to 1	depends upon the make	is more than 1
Condensing temperature in a refrigerator is the temperature	of cooling medium	of freezing zone	at which refrigerant gas becomes liquid	condensing temperature of ice	condensing temperature of ice
The higher temperature in vapour compression cycle occurs at	receiver	expansion valve	evaporator	compressor discharge	compressor discharge
In a flooded evaporator refrigerator, an accumulator at suction of compressor is used to	collect liquid refrigerant and prevent it from going to compressor	detect liquid in vapour	superheat the vapour	collect vapours	collect liquid refrigerant and prevent it from going to compressor

Domestic refrigerator working on vapour compression cycle uses the following type of expansion device	electrically operated throttling valve	manually operated valve	capillary tube	expansion valve.	capillary tube
The vapour pressure of refrigerant should be	lower than atmospheric pressure	higher than atmospheric pressure	equal to atmospheric pressure	could be anything	higher than atmospheric pressure
At lower temperatures and pressures, the latent heat of vaporisation of a refrigerant	decreases	increases	remains same	depends on other factors	increases
The moisture in a refrigerant is removed by	evaporator	safety relief valve	dehumidifier	driers	driers
Ammonia-absorption refrigeration cycle requires	very little work input	maximum work input	nearly same work input as for vapour compression cycle	zero work input	very little work input
In vapour compression cycle, the condition of refrigerant is high pressure saturated liquid	after passing through the condenser	before passing through the condenser	after passing through the expansion or throttle valve	before entering the expansion valve	before entering the expansion valve

In vapour compression cycle, the condition of refrigerant is very wet vapour	after passing through the condenser	before passing through the condenser	before entering the compressor.	after passing through the expansion or throttle valve	before entering the compressor.
Critical temperature is' the temperature above which	a gas will never liquefy	a gas will immediately liquefy	water will evaporate	water will never evaporate	a gas will never liquefy
Clapeyron equation is a relation between	temperature, pressure and enthalpy	specific volume and enthalpy	temperature and enthalpy	temperature, pressure, specific value and enthalpy	temperature, pressure, specific value and enthalpy
In S.J. unit, one ton of refrigeration is equal to	210 kJ/min	21 kJ/min	420 kJ/min	105 kJ/min.	210 kJ/min
One ton of refrigeration is equal to the refrigeration effect corresponding to melting of 1000 kg of ice	in 1 hour	in 1 minute	in 12 hours	in 24 hours	in 24 hours
The boiling point of ammonia is	(-100)°C	(-50)°C	(-33.3)°C	0°C	(-33.3)°C
The vapour compression refrigerator employs the following cycle	Rankine	Reversed Carnot	Carnot	Reversed Rankine	Reversed Carnot

## 15BEME501

Allowable pressure on high-pressure side or ammonia absorption system is of the order of	atmospheric pressure	2-4 bars	5-6 bars	7-10 bars.	5-6 bars
The refrigerant for a refrigerator should have	high sensible heat	low sensible heat	high latent heat	low latent heat	high latent heat
The relative coefficient of performance is	actual COP/theoretical COP	theoretical COP/actual COP	actual COP x theoretical COP	1-actual COP x theoretical COP	actual COP/theoretical COP
One ton refrigeration corresponds to	50 kcal/min	50 kcal/hr	80 kcal/min	80 kcal/hr	50 kcal/min
An important characteristic of absorption system of refrigeration is	noisy operation	quiet operation	very little power consumption	its input only in the form of heating	quiet operation
In vapour compression cycle using NH3 as refrigerant, initial charge is filled at	suction of compressor	delivery of compressor	high pressure side colse to receiver	low pressure side near receiver	high pressure side colse to receiver

In vapour compression refrigeration system, refrigerant occurs as liquid between	condenser and expansion valve	compressor and evaporator	expansion valve and evaporator	compressor and condenser	expansion valve and evaporator
Freon group of refrigerants are	inflammable	toxic	non- inflammable and toxic	non-toxic and non- inflammable	non-toxic and non- inflammable
Super heating in a refrigeration cycle	increases COP	decreases COP	COP remains unaltered	other factors decide COP	decreases COP
A certain refrigerating system has a normal operating suction pressure of 10 kg/cm gauge and condensing pressure of about 67 kg/cm. The refrigerant used is	Ammonia	Carbon dioxide	Freon	Brine	Carbon dioxide
Efficiency of a Cornot engine is given as 80%. If the- cycle direction be reversed, what will be the value of COP of reversed Carnot cycle	1.25	0.8	0.5	0.25	0.25
Where does the lowest temperature occur in a vapour compression cycle ?	condenser	evaporator	compressor	expansion valve	expansion valve

## 15BEME501

Aqua ammonia is used as refrigerant in the following type of refrigeration system	compression	direct	indirect	absorption	absorption
Which of the following is not a desirable property of a refrigerant	high triiscibility with oil	low boiling point	good electrical conductor	large latent heat	good electrical conductor
Mass flow ratio of NH3 in comparison to Freon-12 for same refrigeration load and same temperature limits is of the order of	1:1	1:9	9:1	1:3	1:9
The COP of a vapour compression plant in comparison to vapour absorption plant is	more	less	same	unpredictable.	more
For obtaining high COP, the pressure range of compressor should be	high	low	optimum	any value	low
Which of the following refrigerants has lowest freezing point	Freon-12	NH3	C02	Freon-22	Freon-22
Under-cooling in a refrigeration cycle	increases COP	decreases COP	COP remains unaltered	other factors decide COP	increases COP
What is the amount of heat energy required to evaporate 1 pound of water?	370 btu	570 btu	770 btu	970 btu	970 btu

## HEAT POWER ENGINEERING

## 15BEME501

What btu of heat is required to raise 1					
pound of ice 1 degree F when the	0.25	0.5	1	1.5	0.5
temperature is below 32 degrees F?					